

Licence 11149  
 Link to Licence <http://www.environment.nsw.gov.au/prpoeoapp/>  
 Name OneSteel Wire Pty Ltd (Administrator Appointed)  
 Address Industrial Drive, Mayfield, NSW, 2304  
 Location of Monitoring Point/Area Point 1

Monthly Summary for:

Oct-17

Sample Received

Monthly sample received 05/10/17 Other daily and continuous measurements performed through October 2017 .

Data Obtained

11-Nov-17

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured				Exceedance (Y/N)	Comments
			during month	Min value	Max value	100 percentile limit		
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	30	N	
Total Copper	micrograms/L	Monthly	1	N/A	2	N/A	N	
Total Iron	mg/L	Monthly	1	N/A	0.3	2	N	
Total Lead	micrograms/L	Monthly	1	N/A	4	50	N	
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A	2	20	N	
Total Zinc	mg/L	Monthly	1	N/A	<0.1	2	N	
pH	pH	Continuous	Continuous	7.7	8.3	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A	41	42	N	
Volume	kL/day	Daily	Daily	58	466	700	N	

Licence 11149  
 Link to Licence <http://www.environment.nsw.gov.au/prpoeoapp/>  
 Name OneSteel Wire Pty Ltd (Administrator Appointed)  
 Address Industrial Drive, Mayfield, NSW, 2304

Location of Monitoring Point/Area Point 39

Monthly Summary for: Oct-17  
 Sample Received Monthly sample received 05/10/2017 . Oil and grease 05/10/2017.  
 Other daily and continuous measurements performed through October 2017.

Data Obtained 11-Nov-17

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured		100 percentile limit	Exceedance (Y/N)	Comments
			during month	Min value			
Chromium (hexavalent)	mg/L	Monthly	1	N/A	<0.005	0.01	N
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	N/A	N
Phosphate	mg/L	Monthly	1	N/A	0.49	10	N
Total Copper	micrograms/L	Monthly	1	N/A	5	N/A	N
Total Iron	mg/L	Monthly	1	N/A	<0.1	5	N
Total Lead	micrograms/L	Monthly	1	N/A	1	N/A	N
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N
Total Suspended Solids	mg/L	Monthly	1	N/A	2	50	N
Total Zinc	mg/L	Monthly	1	N/A	0.3	3	N
Oil and Grease	mg/L	Monthly	1	N/A	5	20	N
pH	pH	Continuous	Continuous	7.2	7.5	6.5-8.5	N
Temperature	degrees Celsius	Continuous	Continuous	N/A	35.4	38	N
Volume	kL/day	Daily	Daily	0	297.5	200	N

One rainfall discharge on 21 Oct as per Licence condition L3.2