

Licence 11149
 Link to Licence <http://app.epa.nsw.gov.au/prpoeoapp/>
 Name Liberty Steel -Wire
 Address Industrial Drive, Mayfield, NSW, 2304
 Location of Monitoring Point/Area Point 1

Monthly Summary for: Nov-18
 Sample Received Monthly sample received 15/11/18 Other daily and continuous measurements performed through November 2018 .
 Data Obtained 06-Nov-18

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured during month	Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
Nitrogen (ammonia)	mg/L	Monthly	1	N./A	<1	30	N	
Total Copper	micrograms/L	Monthly	1	N./A	3	N/A	N	
Total Iron	mg/L	Monthly	1	N./A	0.3	2	N	
Total Lead	micrograms/L	Monthly	1	N./A	4	50	N	
Total Manganese	mg/L	Monthly	1	N./A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N./A	2	20	N	
Total Zinc	mg/L	Monthly	1	N./A	<0.1	2	N	
pH	pH	Continuous	Continuous	7.7	8.3	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A	42	42	N	
Volume	kL/day	Daily	Daily	100	492	700	N	

Licence 11149
 Link to Licence <http://app.epa.nsw.gov.au/prpoeoapp/>
 Name Liberty Steel- Wire
 Address Industrial Drive, Mayfield, NSW, 2304
 Location of Monitoring Point/Area Point 39
 Monthly Summary for: Nov-18
 Sample Received Monthly sample received 12/11/2018 . Oil and grease 08/11/2018.
 Other daily and continuous measurements performed through November 2018.
 Data Obtained 22-Nov-18

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured		100 percentile limit	Exceedance (Y/N)	Comments
			during month	Min value			
Chromium (hexavalent)	mg/L	Monthly	1	N/A	<0.005	0.01	N
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	N/A	N
Phosphate	mg/L	Monthly	1	N/A	2.5	10	N
Total Copper	micrograms/L	Monthly	1	N/A	0.004	N/A	N
Total Iron	mg/L	Monthly	1	N/A	0.1	5	N
Total Lead	micrograms/L	Monthly	1	N/A	<1	N/A	N
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N
Total Suspended Solids	mg/L	Monthly	1	N/A	<1	50	N
Total Zinc	mg/L	Monthly	1	N/A	0.2	3	N
Oil and Grease	mg/L	Monthly	1	N/A	6	20	N
pH	pH	Continuous	Continuous	7.36	7.75	6.5-8.5	N
Temperature	degrees Celsius	Continuous	Continuous	N/A	33.5	38	N
Volume	kL/day	Daily	Daily	0	198.3	200	N

Note: There were 8 discharges for the month, nil Maintenance .