

Licence 11149
 Link to Licence <http://app.epa.nsw.gov.au/prpoeoapp/>
 Name Liberty Steel -Wire
 Address Industrial Drive, Mayfield, NSW, 2304
 Location of Monitoring Point/Area Point 1

Monthly Summary for: Jan-19
 Sample Received Monthly sample received 15/1/19 Other daily and continuous measurements performed through January 2019
 Data Obtained 02-Feb-19

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured		Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
			during month						
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	30	N		
Total Copper	micrograms/L	Monthly	1	N/A	4	N/A	N		
Total Iron	mg/L	Monthly	1	N/A	0.2	2	N		
Total Lead	micrograms/L	Monthly	1	N/A	1	50	N		
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N		
Total Suspended Solids	mg/L	Monthly	1	N/A	2	20	N		
Total Zinc	mg/L	Monthly	1	N/A	<0.1	2	N		
pH	pH	Continuous	Continuous	7.7	8.3	6.5-8.5	N		
Temperature	degrees Celsius	Continuous	Continuous	N/A	41.9	42	N		
Volume	kL/day	Daily	Daily	0	405	700	N		

Licence 11149
 Link to Licence <http://app.epa.nsw.gov.au/prpoeoapp/>
 Name Liberty Steel- Wire
 Address Industrial Drive, Mayfield, NSW, 2304
 Location of Monitoring Point/Area Point 39
 Monthly Summary for: Jan-19
 Sample Received Monthly sample received 7/1/2019 . Oil and grease 14/1/2019.
 Other daily and continuous measurements performed through January 2019.
 Data Obtained 02-Feb-19

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured		100 percentile limit	Exceedance (Y/N)	Comments
			during month	Min value			
Chromium (hexavalent)	mg/L	Monthly	1	N/A	<0.005	0.01	N
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	N/A	N
Phosphate	mg/L	Monthly	1	N/A	0.97	10	N
Total Copper	micrograms/L	Monthly	1	N/A	5	N/A	N
Total Iron	mg/L	Monthly	1	N/A	0.4	5	N
Total Lead	micrograms/L	Monthly	1	N/A	<1	N/A	N
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N
Total Suspended Solids	mg/L	Monthly	1	N/A	2	50	N
Total Zinc	mg/L	Monthly	1	N/A	0.3	3	N
Oil and Grease	mg/L	Monthly	1	N/A	6	20	N
pH	pH	Continuous	Continuous	7.3	8.1	6.5-8.5	N
Temperature	degrees Celsius	Continuous	Continuous	N/A	36	38	N
Volume	kL/day	Daily	Daily	0	197	200	N

Note: Eight normal discharges , nil rain or maintenance discharges.