

Licence 11149  
 Link to Licence <http://app.epa.nsw.gov.au/prpoeoapp/>  
 Name **InfraBuild -Wire**  
 Address Industrial Drive, Mayfield, NSW, 2304  
 Location of Monitoring Point/Area **Point 1**

Monthly Summary for: **Aug-20**  
 Sample Received Monthly sample received 4/8/20 Other daily and continuous measurements performed through August 2020  
 Data Obtained 01/09/2020

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured			100 percentile limit	Exceedance (Y/N)	Comments
			during month	Min value	Max value			
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	30	N	
Total Copper	micrograms/L	Monthly	1	N/A	2	N/A	N	
Total Iron	mg/L	Monthly	1	N/A	0.17	2	N	
Total Lead	micrograms/L	Monthly	1	N/A	2	50	N	
Total Manganese	mg/L	Monthly	1	N/A	0.009	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A	2	20	N	
Total Zinc	mg/L	Monthly	1	N/A	0.048	2	N	
pH	pH	Continuous	Continuous	7.7	8.3	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A	35	42	N	
Volume	kL/day	Daily	Daily	84	357	700	N	

Licence 11149  
 Link to Licence <http://app.epa.nsw.gov.au/prpoeoapp/>  
 Name **InfraBuild - Wire**  
 Address Industrial Drive, Mayfield, NSW, 2304  
 Location of Monitoring Point/Area **Point 39**

Monthly Summary for: **Aug-20**  
 Sample Received Monthly sample received 5/8/20 . Oil and Grease 5/08/2020 .  
 Other daily and continuous measurements performed through August 2020.

Data Obtained 01/09/2020

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured during month		Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
Chromium (hexavalent)	mg/L	Monthly	1	N/A	N/A	0.01	N	Chrome removed from Licence requirements 3/12/2019	
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	N/A	N		
Phosphorus	mg/L	Monthly	1	N/A	0.56	10	N		
Total Copper	micrograms/L	Monthly	1	N/A	4	N/A	N		
Total Iron	mg/L	Monthly	1	N/A	0.07	5	N		
Total Lead	micrograms/L	Monthly	1	N/A	<1	N/A	N		
Total Manganese	mg/L	Monthly	1	N/A	0.006	0.5	N		
Total Suspended Solids	mg/L	Monthly	1	N/A	1	50	N		
Total Zinc	mg/L	Monthly	1	N/A	0.23	3	N		
Oil and Grease	mg/L	Monthly	1	N/A	<5	20	N		
pH	pH	Continuous	Continuous	7.2	7.6	6.5-8.5	N		
Temperature	degrees Celsius	Continuous	Continuous	N/A	29.4	38	N		
Volume	kL/day	Daily	Daily	0	321*	200	N		

**Note:** \*One Maintenance discharge on the 31 st August .  
 This is allowable under Licence condition L3.2 .