

Licence 11149  
 Link to Licence <http://app.epa.nsw.gov.au/prpoeoapp/>  
 Name **InfraBuild -Wire**  
 Address Industrial Drive, Mayfield, NSW, 2304  
 Location of Monitoring Point/Area **Point 1**

Monthly Summary for: **Sep-20**  
 Sample Received Monthly sample received 2/9/20 Other daily and continuous measurements performed through September 2020  
 Data Obtained 01/10/2020

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured				Exceedance (Y/N)	Comments
			during month	Min value	Max value	100 percentile limit		
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	2	30	N	
Total Copper	micrograms/L	Monthly	1	N/A	4	N/A	N	
Total Iron	mg/L	Monthly	1	N/A	0.5	2	N	
Total Lead	micrograms/L	Monthly	1	N/A	6	50	N	
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A	5	20	N	
Total Zinc	mg/L	Monthly	1	N/A	<0.1	2	N	
pH	pH	Continuous	Continuous	7.7	8.24	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A	36.5	42	N	
Volume	kL/day	Daily	Daily	69	354	700	N	

Licence 11149  
 Link to Licence <http://app.epa.nsw.gov.au/prpoeoapp/>  
 Name **InfraBuild - Wire**  
 Address Industrial Drive, Mayfield, NSW, 2304  
 Location of Monitoring Point/Area **Point 39**

Monthly Summary for: **Sep-20**  
 Sample Received Monthly sample received 2/9/20 . Oil and Grease 3/9/2020 .  
 Other daily and continuous measurements performed through September 2020.

Data Obtained 01/10/2020

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured during month	Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
Chromium (hexavalent)	mg/L	Monthly	1	N/A		0.01	N	Chrome removed from Licence requirements 3/12/2019
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	N/A	N	
Phosphorus	mg/L	Monthly	1	N/A	0.77	10	N	
Total Copper	micrograms/L	Monthly	1	N/A	4	N/A	N	
Total Iron	mg/L	Monthly	1	N/A	0.1	5	N	
Total Lead	micrograms/L	Monthly	1	N/A	<1	N/A	N	
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A	2	50	N	
Total Zinc	mg/L	Monthly	1	N/A	0.4	3	N	
Oil and Grease	mg/L	Monthly	1	N/A	<5	20	N	
pH	pH	Continuous	Continuous	7.3	7.7	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A	34.8	38	N	
Volume	kL/day	Daily	Daily	0	198.4	200	N	

**Note:**