

Licence 11149
 Link to Licence <http://app.epa.nsw.gov.au/prpoeoapp/>
 Name **InfraBuild -Wire**
 Address Industrial Drive, Mayfield, NSW, 2304
 Location of Monitoring Point/Area **Point 1**

Monthly Summary for: **Dec-20**
 Sample Received Monthly sample received 2/12/20. Other daily and continuous measurements performed through December 2020
 Data Obtained 05/01/2021

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured		Max value	100 percentile limit	Exceedance (Y/N)	Comments
			during month	Min value				
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	30	N	
Total Copper	micrograms/L	Monthly	1	N/A	3	N/A	N	
Total Iron	mg/L	Monthly	1	N/A	0.1	2	N	
Total Lead	micrograms/L	Monthly	1	N/A	1	50	N	
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A	2	20	N	
Total Zinc	mg/L	Monthly	1	N/A	<0.1	2	N	
pH	pH	Continuous	Continuous	7.7	8.5	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A	39.9	42	N	
Volume	kL/day	Daily	Daily	0	404	700	N	

Licence 11149
 Link to Licence <http://app.epa.nsw.gov.au/prpoeoapp/>
 Name **InfraBuild - Wire**
 Address Industrial Drive, Mayfield, NSW, 2304
 Location of Monitoring Point/Area **Point 39**

Monthly Summary for: **Dec-20**
 Sample Received Monthly sample received 2/12/20 . Oil and Grease 3/12/2020 .
 Other daily and continuous measurements performed through December 2020.

Data Obtained 05/01/2021

Pollutant	Units of Measure	Monitoring	No of times		100 percentile limit	Exceedance (Y/N)	Comments	
		frequency required by Licence	during month	Min value				Max value
Chromium (hexavalent)	mg/L	Monthly		N/A	N/A	0.01	N	Chrome removed from Licence requirements 3/12/2019
Nitrogen (ammonia)	mg/L	Monthly	3	<1	<1	N/A	N	
Phosphorus	mg/L	Monthly	3	1.3	1.9	10	N	
Total Copper	micrograms/L	Monthly	3	16	33	N/A	N	
Total Iron	mg/L	Monthly	3	0.1	4.4	5	N	
Total Lead	micrograms/L	Monthly	3	<1	2	N/A	N	
Total Manganese	mg/L	Monthly	3	<0.1	0.2	0.5	N	
Total Suspended Solids	mg/L	Monthly	3	1	47	50	N	
Total Zinc	mg/L	Monthly	3	0.1	0.3	3	N	
Oil and Grease	mg/L	Monthly	2	<5	<5	20	N	LOR 5
pH	pH	Continuous	Continuous	7.3	7.8	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A	37.6	38	N	
Volume	kL/day	Daily	Daily	0	959	200	N	Maintenance discharge

Note: 2 Days of Maintenance discharge under Licence condition L3.2.