

Licence 11149
 Link to Licence <http://app.epa.nsw.gov.au/prpoeoapp/>
 Name **InfraBuild -Wire**
 Address Industrial Drive, Mayfield, NSW, 2304
 Location of Monitoring Point/Area **Point 1**

Monthly Summary for: **Feb-21**
 Sample Received Monthly sample received 2/2/21. Other daily and continuous measurements performed through February 2021
 Data Obtained 02/03/2021

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured		Max value	100 percentile limit	Exceedance (Y/N)	Comments
			during month	Min value				
Nitrogen (ammonia)	mg/L	Monthly	6	0.57	2.64	30	N	
Total Copper	micrograms/L	Monthly	6	2	5	N/A	N	
Total Iron	mg/L	Monthly	6	<0.1	0.2	2	N	
Total Lead	micrograms/L	Monthly	6	1	3	50	N	
Total Manganese	mg/L	Monthly	6	<0.1	0.2	0.5	N	
Total Suspended Solids	mg/L	Monthly	6	2	4	20	N	
Total Zinc	mg/L	Monthly	6	<0.1	0.2	2	N	
pH	pH	Continuous	Continuous	7.38	8.3	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A	41	42	N	
Volume	kL/day	Daily	Daily	15	385	700	N	

Licence 11149
 Link to Licence <http://app.epa.nsw.gov.au/prpoeoapp/>
 Name **InfraBuild - Wire**
 Address Industrial Drive, Mayfield, NSW, 2304
 Location of Monitoring Point/Area **Point 39**

Monthly Summary for: **Feb-21**
 Sample Received Monthly sample received 3/2/21 . Oil and Grease 4/2/2021 .
 Other daily and continuous measurements performed through February 2021.

Data Obtained 03/03/2021

Pollutant	Units of Measure	Monitoring	No of times		100 percentile limit	Exceedance (Y/N)	Comments	
		frequency required by Licence	during month	Min value				Max value
Chromium (hexavalent)	mg/L	Monthly	1	N/A	0.01	N	Chrome removed from Licence requirements 3/12/2019	
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	N		
Phosphorus	mg/L	Monthly	1	N/A	1.1	N		
Total Copper	micrograms/L	Monthly	1	N/A	3	N		
Total Iron	mg/L	Monthly	1	N/A	<0.1	N		
Total Lead	micrograms/L	Monthly	1	N/A	<1	N		
Total Manganese	mg/L	Monthly	1	N/A	<0.1	N		
Total Suspended Solids	mg/L	Monthly	1	N/A	2	N		
Total Zinc	mg/L	Monthly	1	N/A	0.1	N		
Oil and Grease	mg/L	Monthly	1	N/A	6	N		
pH	pH	Continuous	Continuous	7.3	7.95	6.5-8.5		N
Temperature	degrees Celsius	Continuous	Continuous	N/A	36.7	38		N
Volume	kL/day	Daily	Daily	0	197	200		N

Note: