

Licence 11149
 Link to Licence <http://app.epa.nsw.gov.au/prpoeoapp/>
 Name **InfraBuild -Wire**
 Address Industrial Drive, Mayfield, NSW, 2304

Location of Monitoring Point/Area **Point 1**

Monthly Summary for:

Mar-21

Sample Received

8 x Composite samples received during March . Daily and continuous measurements performed through March 2021

Data Obtained

02/04/2021

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured		Max value	100 percentile limit	Exceedance (Y/N)	Comments
			during month	Min value				
Nitrogen (ammonia)	mg/L	Monthly	8	0.03	1.94	30	N	
Total Copper	micrograms/L	Monthly	8	1	11	N/A	N	
Total Iron	mg/L	Monthly	8	0.2	0.4	2	N	
Total Lead	micrograms/L	Monthly	8	<1	4	50	N	
Total Manganese	mg/L	Monthly	8	<0.1	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	8	1	5	20	N	
Total Zinc	mg/L	Monthly	8	<0.1	<0.1	2	N	
pH	pH	Continuous	Continuous	7.3	8.3	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A	39	42	N	
Volume	kL/day	Daily	Daily	27	406	700	N	

Licence 11149
 Link to Licence <http://app.epa.nsw.gov.au/prpoeoapp/>
 Name **InfraBuild - Wire**
 Address Industrial Drive, Mayfield, NSW, 2304
 Location of Monitoring Point/Area **Point 39**

Monthly Summary for: **Mar-21**
 Sample Received Monthly sample received 3/3/21 . Oil and Grease 5/3/2021 .
 Other daily and continuous measurements performed through March 2021.

Data Obtained 06/04/2021

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured during month	Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
Chromium (hexavalent)	mg/L	Monthly	1	N/A		0.01	N	Chrome removed from Licence requirements 3/12/2019
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	N/A	N	
Phosphorus	mg/L	Monthly	1	N/A	<0.05	10	N	
Total Copper	micrograms/L	Monthly	1	N/A	3	N/A	N	
Total Iron	mg/L	Monthly	1	N/A	0.1	5	N	
Total Lead	micrograms/L	Monthly	1	N/A	<1	N/A	N	
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A	1	50	N	
Total Zinc	mg/L	Monthly	1	N/A	0.2	3	N	
Oil and Grease	mg/L	Monthly	1	N/A	6	20	N	
pH	pH	Continuous	Continuous	7.3	7.7	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A	35	38	N	
Volume	kL/day	Daily	Daily	0	485*	200	N	wet weather

Note: *4 Wet weather discharges due to high rainfall , permitted under section L3.3 of Licence 11149.