Licence 11149

Link to Licence http://app.epa.nsw.gov.au/prpoeoapp/

Name InfraBuild -Wire

Address Industrial Drive, Mayfield, NSW, 2304

Location of Monitoring Point/Area Point 1

Monthly Summary for: Nov-21

Sample Received 9 x Composite samples received during November . Daily and continuous measurements performed through November 2021

Data Obtained 08/12/2021

Pollutant	Units of Measure	frequency required	No of times measured during month	Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
Nitrogen (ammonia)	mg/L	Monthly	9	0.22	2.9	30	N	
Total Copper	micrograms/L	Monthly	9	2	8	N/A	N	
Total Iron	mg/L	Monthly	9	0.2	1.2	2	N	
Total Lead	micrograms/L	Monthly	9	<1	3	50	N	
Total Manganese	mg/L	Monthly	9	0.008	0.04	0.5	N	
Total Suspended Solids	mg/L	Monthly	9	2	11	20	N	
Total Zinc	mg/L	Monthly	9	0.009	0.065	2	N	
рН	pH	Continuous	Continuous	7.7	8.3	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	14.3	42	42	N	
Volume	kL/day	Daily	Daily	50	396.8	700	N	

InfraBuild

Licence 11149

Link to Licence http://app.epa.nsw.gov.au/prpoeoapp/

Address Industrial Drive, Mayfield, NSW, 2304



Monthly Summary for: Nov-21

Sample Received Monthly sample received 2/11/21. Oil and Grease 2/11/2021.

Other daily and continuous measurements performed through November 2021.

Data Obtained 07/12/2021

Pollutant	Units of Measure	frequency required		Bilin volue	Max value	400 manantila limit	Evendence (V/N)	Comments
Poliutant	Units of Measure	by Licence	during month	win value	wax value	100 percentile limit	Exceedance (Y/N)	Comments
								Chrome removed
								from Licence
								requirements
Chromium (hexavalent)	mg/L	Monthly	1	N/A		0.01	N	3/12/2019
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	N/A	N	
Phosphorus	mg/L	Monthly	1	N/A	0.92	10	N	
Total Copper	micrograms/L	Monthly	1	N/A	3	N/A	N	
Total Iron	mg/L	Monthly	1	N/A	0.1	5	N	
Total Lead	micrograms/L	Monthly	1	N/A	<1	N/A	N	
Total Manganese	mg/L	Monthly	1	N/A	<0.005	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A	<1	50	N	
Total Zinc	mg/L	Monthly	1	N/A	0.2	3	N	
Oil and Grease	mg/L	Monthly	1	N/A	<5	20	N	
pH	pH	Continuous	Continuous	7.2	7.9	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A	31.8	38	N	
Volume	kL/day	Daily	Daily	0	292.1	200	N	

InfraBuild

Note: One wet weather discharge on the 7 th of November under Licence condition L3.3