

2nd Quarter Emissions Testing Report 2019

Liberty Recycling Hexham



NATA ACCREDITATION No. 2778 (14391)

Accredited for compliance with ISO/IEC 17025 – Testing

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

This document may not be reproduced except in full.

2nd Quarter Emissions Testing Report 2019

Liberty Recycling Hexham

Client: Liberty Recycling Pty Ltd

ABN: 28 002 707 262

Prepared by

AECOM Australia Pty Ltd

17 Warabrook Boulevard, Warabrook NSW 2304, PO Box 73, Hunter Region MC NSW 2310, Australia
T +61 2 4911 4900 F +61 2 4911 4999 www.aecom.com

ABN 20 093 846 925

07-Jun-2019

Job No.: 60493017

AECOM in Australia and New Zealand is certified to ISO9001, ISO14001 AS/NZS4801 and OHSAS18001.

© AECOM Australia Pty Ltd (AECOM). All rights reserved.

AECOM has prepared this document for the sole use of the Client and for a specific purpose, each as expressly stated in the document. No other party should rely on this document without the prior written consent of AECOM. AECOM undertakes no duty, nor accepts any responsibility, to any third party who may rely upon or use this document. This document has been prepared based on the Client's description of its requirements and AECOM's experience, having regard to assumptions that AECOM can reasonably be expected to make in accordance with sound professional principles. AECOM may also have relied upon information provided by the Client and other third parties to prepare this document, some of which may not have been verified. Subject to the above conditions, this document may be transmitted, reproduced or disseminated only in its entirety.

Quality Information

Document 2nd Quarter Emissions Testing Report 2019

Ref 60493017

Date 07-Jun-2019

Prepared by Sharn Crosdale

Reviewed by Paul Wenta

AECOM Approved Signatory Chad Whitburn



Revision History


Rev	Revision Date	Details	Authorised	
			Name/Position	Signature
0	07-Jun-19	Report for Issue	Chad Whitburn Associate Director - Compliance Services	

Table of Contents

1.0	Introduction	1
2.0	Sampling Plane Requirements	2
3.0	Methodology	3
3.1	NATA Accredited Methods	3
3.2	Equipment Calibration	3
4.0	Sampling Location	4
4.1	Sampling Location Summary	4
5.0	Results	5
Appendix A		
	Field Sheets (16 pages)	A
Appendix B		
	Laboratory Results (8 pages)	B

List of Tables

Table 1	Criteria for Selection of Sampling Planes (AS 4323.1)	2
Table 2	AECOM NATA Endorsed Methods	3
Table 3	Sampling Location Summary	4
Table 4	Shredder Baghouse Emission Results Summary, 22 May 2019	5
Table 5	Fine Particulate (PM ₁₀), Total Particulate and Hazardous Substance (Metals) Results, 22 May 2019	6
Table 6	Hazardous Substances (Metals) Elemental Analysis Results, 22 May 2019	7

1.0 Introduction

AECOM was appointed by Liberty Recycling Pty Ltd to conduct a series of measurements to determine air emissions from the Shredder Baghouse Stack (EPL Point 1) at the Hexham facility. Measurements were required for NSW EPA licence compliance (EPL No. 5345).

Testing was undertaken on 22 May 2019 to investigate emission concentrations for the following parameters:

- Fine Particulates (PM₁₀);
- Total Particulate (TP); and
- Hazardous Substances (Metals) including Lead and Mercury.

Laboratory analysis was undertaken by the following laboratories which hold NATA accreditation for the specified tests:

- Steel River Testing, laboratory NATA accreditation number 18079, performed the following analysis detailed in report number 18854-0-M & 18854-0-P:
 - Total Particulate (TP);
 - Fine Particulates (PM₁₀); and
 - Moisture.
- SGS Australia Pty Ltd, NATA accreditation number 2562, performed the following analysis detailed in report number ME310641 R0:
 - Hazardous Substances (Metals).

2.0 Sampling Plane Requirements

The criteria for sampling planes are specified in AS 4323.1-1995 (R2014).

Table 1 Criteria for Selection of Sampling Planes (AS 4323.1)

Type of flow disturbance	Minimum distance upstream from disturbance, diameters (D)	Minimum distance downstream from disturbance, diameters (D)
Bend, connection, junction, direction change	>2D	>6D
Louvre, butterfly damper (partially closed or closed)	>3D	>6D
Axial fan	>3D	>8D (see Note)
Centrifugal fan	>3D	>6D

NOTE: The plane should be selected as far as practicable from a fan. Flow straighteners may be required to ensure the position chosen meets the check criteria listed in Items (a) to (f) below.

- The gas flow is basically in the same direction at all points along each sampling traverse;*
- The gas velocity at all sampling points is greater than 3 m/s;*
- The gas flow profile at the sampling plane shall be steady, evenly distributed and not have a cyclonic component which exceeds an angle of 15° to the duct axis, when measured near the periphery of a circular sampling plane;*
- The temperature difference between adjacent points of the survey along each sampling traverse is less than 10% of the absolute temperature, and the temperature at any point differs by less than 10% from the mean;*
- The ratio of the highest to lowest pitot pressure difference shall not exceed 9:1 and the ratio of highest to lowest gas velocities shall not exceed 3:1. For isokinetic testing with the use of impingers, the gas velocity ratio across the sampling plane should not exceed 1.6:1; and*
- The gas temperature at the sampling plane should preferably be above the dewpoint.*

The sampling plane for EPL Point 1 was compliant with the AS4323.1.

3.0 Methodology

3.1 NATA Accredited Methods

The following methods are accredited with the National Association of Testing Authorities (NATA) (accreditation number 2778 (14391)) and are approved for the sampling and analysis of gases. Specific details of the methods are available on request.

All sampling and analysis is conducted according to the methods in **Table 2**.

Table 2 AECOM NATA Endorsed Methods

NSW EPA Approved Methods	USEPA Methods	Method Title
AS4323.1	USEPA (2000) Method 1	Selection of sampling positions
AS4323.2	USEPA (2000) Method 5	Determination of total particulate matter – isokinetic manual sampling – gravimetric method
NSW EPA TM-2	USEPA (2000) Method 2	Determination of stack gas velocity and volumetric flow rate (type s pitot tube)
NSW EPA TM-22	USEPA (2000) Method 4	Determination of moisture content in stack gases
NSW EPA TM-23	USEPA (2000) Method 3	Gas analysis for the determination of dry molecular weight
NSW EPA OM-5	USEPA (1997) Method 201A	Determination of PM ₁₀ emissions
NSW EPA TM-12,13 and 14	USEPA Method 29	Determination of metal emissions from stationary sources

All parameters are reported adjusted to 0°C at 1 atmosphere and dry gas.

3.2 Equipment Calibration

AECOM has a calibration schedule to ensure the emission testing equipment is maintained in good order and with known calibration. Equipment used in this project was calibrated according to the procedures and frequency identified in the AECOM calibration schedule. Details of the schedule and the calibration calculations are available on request.

4.0 Sampling Location

4.1 Sampling Location Summary

Table 3 provides a summary of the location sampled by AECOM on 22 May 2019.

Table 3 Sampling Location Summary

Discharge Description	Shredder Baghouse Stack (EPL Point 1)
Duct Shape	Circular
Construction Material	Metal
Duct Diameter (mm)	760
Minimum No. Sampling Points	12
Sampling Ports	2
Min. Points/Traverse	6
Disturbance	No
Distance from Upstream Disturbance	6.6D
Type of Disturbance	Bend
Distance from Downstream Disturbance	2.6D
Type of Disturbance	Stack Exit
Ideal Sampling Location	Yes
Correction Factors Applied	No
Total No. Points Sampled	12
Points/Traverse	6
Sampling Performed to Standard ¹	Yes

¹ AS 4323.1 Section 4.1

D = Diameters

5.0 Results

A summary of air emission test results is shown in **Table 4**. Detailed results along with gas stream properties during the testing period can be found in **Table 5**. Speciated Hazardous Substances (Metals) results are presented in **Table 6**. Emission concentrations are converted to standard conditions of 0°C, dry gas and 1 atm pressure for comparison with regulatory limits.

Field sheets and final calculations recorded during the project are attached as **Appendix A**. Laboratory reports can be referred to in **Appendix B**.

AECOM has a calculated limit of uncertainty in regard to results. The estimation of measurement uncertainty in source testing is conducted to provide an indication of the precision of the measurement result and a degree of confidence in the range of values the reported result may represent. The measurement of uncertainty has been calculated at $\pm 13.6\%$.

Table 4 Shredder Baghouse Emission Results Summary, 22 May 2019

Parameter	Emission Concentration (EPL Point 1)	Emission Concentration Limit
Total Particulate (TP) (mg/m ³)	22	100
Fine Particulate (PM ₁₀) (mg/m ³)	8.1	N/A
Lead (mg/m ³)	0.098	5.0
Mercury (mg/m ³)	0.000041	1.0
Total Hazardous Substances (Metals) (mg/m ³)	0.18	N/A

Results from testing conducted on EPL Point 1 on 22 May 2019 are below the regulatory limits listed in EPL 5345.

Table 5 Fine Particulate (PM₁₀), Total Particulate and Hazardous Substance (Metals) Results, 22 May 2019

Sampling Conditions:		
Stack internal diameter at test location	760 mm	296.2 K
Stack gas temperature (average)	23.0 °C	
Stack pressure (average)	1026 hPa	
Stack gas velocity (average, stack conditions)	6.6 m/s	
Stack gas flowrate (stack conditions)	3 m³/s	
Stack gas flowrate (0°C, dry gas, 1 atm pressure)	2.8 m³/s	
Fine Particulate (PM ₁₀) Testing		
Test Period	10:22 -	11:46
Fine Particulate (PM ₁₀) Mass	8.8 mg	
Gas Volume Sampled	1.08 m³	
Fine Particulate (PM ₁₀) Emission* ¹	8.1 mg/m³	
Fine Particulate (PM ₁₀) Mass Emission Rate* ²	23 mg/s	
Regulatory Limit	N/A	
Total Particulate Testing		
Test Period	10:22 -	11:46
Total Particulate Mass	19.7 mg	
Gas Volume Sampled	0.909 m³	
Total Particulate Emission* ¹	22 mg/m³	
Total Particulate Mass Emission Rate* ²	61 mg/s	
Regulatory Limit	100 mg/m³	
Hazardous Substances (Metals) Testing		
Test Period	10:22 -	11:46
Hazardous Substances (Metals) Mass	0.218 mg	
Gas Volume Sampled	1.23 m³	
Hazardous Substances (Metals) Emission* ¹	0.18 mg/m³	
Hazardous Substances (Metals) Mass Emission Rate* ²	0.5 mg/s	
Regulatory Limit	N/A	
Moisture Content (%)		
Gas Density (dry at 1 atmosphere)	0.2	
Dry Molecular Weight	1.29 kg/m³	
	28.8 g/g-mole	

Notes *1 Emission concentration at Standard conditions of 0°C, 1 atm, dry gas

*2 Mass emission rate determined from pre and post-test sampling flow measurements and the respective test moisture content. See Q_{std} in field sheets and final calculations "Stack Analysis - Final Calculations" for each test.

Table 6 Hazardous Substances (Metals) Elemental Analysis Results, 22 May 2019

Sample	Total Particulate Metals (mg)	Total Particulate Metals (mg/m ³)	Total Gaseous Metals (mg)	Total Gaseous Metals (mg/m ³)	Total Oxidisable Mercury (mg)	Total Oxidisable Mercury (mg/m ³)	Total (mg)	Total (mg/m ³)	Mass Emission Rate (mg/s)
Antimony	0.0010	0.00085	0.0003	0.0002			0.0013	0.0011	0.0030
Arsenic	0.00023	0.00019	<0.0002	<0.000163			0.00023	0.00019	0.00052
Beryllium	<0.00007	<0.0000571	<0.0001	<0.0000816			<0.0001	<0.0000816	<0.000227
Cadmium	0.0028	0.0022	0.00085	0.00069			0.0036	0.0029	0.0082
Chromium	0.0012	0.0010	0.0041	0.0034			0.0053	0.0043	0.012
Cobalt	0.0004	0.00036	0.0064	0.0052			0.0068	0.0056	0.015
Copper	0.010	0.0085	0.0031	0.0025			0.013	0.011	0.030
Lead	0.12	0.094	0.0025	0.0020			0.12	0.098	0.27
Magnesium	0.065	0.053	0.0044	0.0036			0.069	0.056	0.16
Manganese	0.015	0.012	0.022	0.018			0.037	0.030	0.084
Mercury	<0.0001	<0.0000816	<0.0001	<0.0000816	0.000050	0.000041	0.000050	0.000041	0.00011
Nickel	0.0033	0.0027	0.039	0.032			0.042	0.034	0.095
Selenium	0.00027	0.00022	<0.0007	<0.000571			0.00027	0.00022	0.0006
Thallium	<0.0001	<0.0000816	<0.0001	<0.0000816			<0.0001	<0.0000816	<0.000227
Tin	0.0015	0.0012	0.00020	0.00016			0.0017	0.0014	0.0039
Vanadium	<0.0017	<0.00139	<0.002	<0.00163			<0.0001	<0.0000816	<0.000227
Zinc	0.48	0.39	0.031	0.025			0.51	0.42	1.2
Total Hazardous Metals*	0.14	0.11	0.075	0.061	0.000050	0.000041	0.22	0.18	0.50
Total Metals	0.70	0.57	0.11	0.093			0.81	0.66	1.8

* Total does not include Copper, Magnesium and Zinc as they are classed non-hazardous

This page has been left blank intentionally.

Appendix A

Field Sheets (16 pages)

Appendix A Field Sheets (16 pages)

Emission Measurement Calculations Spreadsheet

Q4AN(EV)-332-FM31

Liberty Recycling Hexham

AECOM's Project Number: 60493017

Emission Source: Shredder Stack

Date Sampled: 22-May-19

ANALYTE(S)	METHOD
Fine Particulate (PM10)	NSW EPA OM - 5
Total Particulate	NSW EPA TM - 15
Hazardous Substances (Metals)	NSW EPA TM - 12, 13 & 14

Observations made during testing period:

Sampling Performed By:




Sharn Crosdale
for Sam Hamilton

Emission Measurement Calculations Spreadsheet

Q4AN(EV)-332-FM31

STACK ANALYSIS - PRE-SAMPLING

Date: 22-May-19
Client: Liberty Recycling Hexham
AECOM's Project No: 60493017
Stack/Duct Description: Shredder Stack
Test 1: Fine Particulate (PM10)
Test 2: Total Particulate
Test 3: Hazardous Substances (Metals)

Measurement/Observations					
Stack Internal Dimensions:					
Diameter	760 mm		Cross Sectional Area : 0.45 m ²		
OR	Length	Width			
Length/Width (mm)			Minimum No. of		
Equivalent Diameter	N/A	mm	sampling points= 12		
Distance from sampling plane to nearest disturbances:			Total No. of sampling points = 12		
			PM2.5/10= 12		
Upstream (m) = 5			No. of sampling traverses/ports sampled = 2		
No. Diameters = 6.6			PM2.5/10= 2		
Type of Upstream Disturbance: Fan Entry			No. of sampling points on each		
Downstream (m) = 2			traverse/port = 6		
No. Diameters = 2.6			PM2.5/10= 6		
Type of Down Stream Disturbance: Stack Exit					
Position of each sampling point, for each traverse:			Exclusion of any sample point numbers - comments:		
A			B		
PM10/2.5 A			PM2.5/10 B		
No.	Distance from wall	S-type Pitot distances	Distance from wall	S-Type Pitot distances	
1	33	3	33	3	
2	111	81	111	81	
3	225	195	225	195	
4	535	505	535	505	
5	649	619	649	619	
6	727	697	727	697	
7					
8					
9					
10			Check of total points against minimum, (yes/no) - comments:		
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
Signed: 			Checked: 		

Emission Measurement Calculations Spreadsheet

STACK ANALYSIS - GAS COMPOSITION AND DENSITY PRE-SAMPLING

Date: 22-May-19
 Client: Liberty Recycling Hexham
 AECOM's Project No: 60493017
 Stack/Duct Description: Shredder Stack
 Test 1: Fine Particulate (PM10)
 Test 2: Total Particulate
 Test 3: Hazardous Substances (Metals)

Sampling time start: 10:16		Sampling port No.: 1		
Measurement No.	Time sampled	CO (ppm), (dry)	O ₂ (%), (dry)	CO ₂ (%), (dry)
1	10:16	0	20.9	0.0
2	10:17	0	20.9	0.0
3	10:18	0	20.9	0.0
4	10:19	0	20.9	0.0
5	10:20	0	20.9	0.0
6	10:21	0	20.9	0.0
7	10:22	0	20.9	0.0
8	10:23	0	20.9	0.0
Averages:		0.0 ppm	20.9 %	0.0 %

Moisture content (M3): 1.00
 Moisture percentage (M2): 0.20 %

Measurements

CO: 0.0000 %,(dry)	N ₂ : 79.1 %,(dry)
CO ₂ : 0.0 %,(dry)	O ₂ : 20.9 %,(dry)
Gas Compositions converted to wet basis:	
CO: 0.0000 %,(wet)	N ₂ : 78.9 %,(wet)
CO ₂ : 0.0 %,(wet)	O ₂ : 20.9 %,(wet)
H ₂ O: 0.20 % (=M2)	
Therefore, stack gas density (GD) = 1.29 kg/m ³ (0°C, wet, 1 atm pressure)	
Therefore, stack gas density (GD) = 1.29 kg/m ³ (0°C, dry, 1 atm pressure)	

ANZ

Emission Measurement Calculations Spreadsheet

Q4AN(EV)-332-FM31

STACK ANALYSIS - GAS COMPOSITION AND DENSITY POST-SAMPLING

Date: 22-May-19
 Client: Liberty Recycling Hexham
 AECOM's Project No: 60493017
 Stack/Duct Description: Shredder Stack
 Test 1: Fine Particulate (PM10)
 Test 2: Total Particulate
 Test 3: Hazardous Substances (Metals)

Sampling time start: 11:32		Sampling port No.: 1		
Measurement No.	Time sampled	CO (ppm), (dry)	O ₂ (%), (dry)	CO ₂ (%), (dry)
1	11:32	0	20.9	0.0
2	11:33	0	20.9	0.0
3	11:34	0	20.9	0.0
4	11:35	0	20.9	0.0
5	11:36	0	20.9	0.0
6	11:37	0	20.9	0.0
7	11:38	0	20.9	0.0
8	11:39	0	20.9	0.0
Averages:		0.0 ppm	20.9 %	0.0 %

Moisture content (M3): 1.00

Moisture percentage (M2): 0.20 %

Measurements

CO: 0.0000 %,(dry)	N ₂ : 79.1 %,(dry)
CO ₂ : 0.0 %,(dry)	O ₂ : 20.9 %,(dry)
Gas Compositions converted to wet basis:	
CO: 0.0000 %,(wet)	N ₂ : 78.9 %,(wet)
CO ₂ : 0.0 %,(wet)	O ₂ : 20.9 %,(wet)
H ₂ O: 0.20 % (=M2)	
Therefore, stack gas density (GD) = 1.29 kg/m ³ (0°C, wet, 1 atm pressure)	
Therefore, stack gas density (GD) = 1.29 kg/m ³ (0°C, dry, 1 atm pressure)	

Q4AN(EV)-332-FM31

Date: 22-May-19
Client: Liberty Recycling Hexham
AECOM's Project No: 60493017
Stack/Duct Description: Shredder Stack
Test 1: Fine Particulate (PM10)
Test 2: Total Particulate
Test 3: Hazardous Substances (Metals)

Static Pressure (Dwyer) (Pa): kPa
 Static Pressure (U-tube, if required) : 3 mm
 Absolute pressure in stack (hPa) : 1026.29 hPa

STACK ANALYSIS

SAMPLING OF FINE PARTICULATE (PM₁₀)

Date: 22-May-19

Date: 22-May-19
Client: Liberty Recycling Hexham

AECOM's Project No: 60493017

Stack Description No.: Shredder Stack

Sample Nozzle No.:	fine6	Sample Nozzle Area (A _n):	2.44	$\times 10^{-5} \text{ m}^2$
--------------------	-------	---------------------------------------	------	------------------------------

Sample Nozzle No.:	1103	Sample Nozzle Area (mm ²):	21.77
Sampling Port No.:	1 to 2	Thimble No:	N23

Page No: 1 of 1 Blank thimble No: 0

Leak Check (Pre-Sampling)

Meter start: 139.6048 Meter finish: 139.6048 Meter start: 140.7762 Meter finish: 140.7762

Water start:	100:00:45	Water finish:	100:00:45	Water start:	1:00:17:02	Water finish:	1:00:17:02
Time start:	9:55	Time finish:	9:56	Time start:	11:48	Time finish:	11:49

Therefore, leakage rate = no leak L/min Therefore, leakage rate = no leak L/min

(>0.1 l/min. is unacceptable)

(>0.1 l/min. is unacceptable)

Repeat:

Repeat:

Repeat:
Comments:

Repeat:
Comments:

Sampling Record Table

Barometric Pressure: 1028 hPa (start); 1028 hPa (finish)

Meter start:	139.6062	Time start:	10:22
--------------	----------	-------------	-------

Meter correction factor (GMf) : 0.9984

Sampling Position No.	Stopwatch Time at Sampling Position	Distance from far wall (mm)	Isokinetic Flowrate (L/min)	Meter Inlet Temp. (°C)	Meter Outlet Temp. (°C)	Impinger Train Outlet Temp (°C)	Flowrate Attained (Y/N)
1/1	0:07:30	33	13.8	28.0	21.0		Yes
1/2	0:07:00	111	13.8	28.0	23.0		Yes
1/3	0:08:30	225	13.8	28.0	23.0		Yes
1/4	0:07:45	535	13.8	26.0	24.0		Yes
1/5	0:07:30	649	13.8	24.0	24.0		Yes
1/6	0:07:45	727	13.8	25.0	24.0		Yes
2/1	0:05:30	33	13.8	30.0	23.0		Yes
2/2	0:06:00	111	13.8	30.0	23.0		Yes
2/3	0:05:00	225	13.8	30.0	23.0		Yes
2/4	0:07:30	535	13.8	30.0	23.0		Yes
2/5	0:06:30	649	13.8	30.0	23.0		Yes
2/6	0:07:45	727	13.8	31.0	23.0		Yes
Averages				28.3	23.1	no result	

Averages			2016	2017	10/1/2017
Meter Finish:	140.7740		Time Finish:	11:46	

Total Condensate collected:	-10 ml	Silica gel No(s) used:	118
-----------------------------	--------	------------------------	-----

Emission Measurement Calculations Spreadsheet

Q4AN(EV)-332-FM31

STACK ANALYSIS

SAMPLING OF TOTAL PARTICULATE

Date: 22-May-19

Date: 22 May 18
Client: Liberty Recycling Hexham

AECOM's Project No: 60493017

Stack Description No.: Shredder Stack

Sample Nozzle No.: s3

Sampling Port No.: 1 to 2

Page No: 1 of 1

Sample Nozzle Area (A_n): 2.85 $\times 10^{-5} \text{ m}^2$

Thimble No: T30

Blank thimble No:

Leak Check (Pre-Sampling)

Meter start: 5540.0274 Meter finish:

Time start: 9:56 Time finish:

Leak Check (Post Sampling)

Meter start: 5541.0492 Meter finish: 5541.0492

Time start: 11:49 Time finish: 11:50

Therefore, leakage rate = no leak L/min

Therefore, leakage rate = no leak L/min

(>0.1 l/min. is unacceptable)

(>0.1 l/min. is unacceptable)

Repeat:

Repeat:

Comments:

Comments:

Sampling Record Table

Barometric Pressure: 1028 hPa (start):

1028 hPa (finish)

Meter start: 5540.0656

Time start:

10:22

Meter correction factor (GMf) : 1.0020

Sampling Position No.	Stopwatch Time at Sampling Position	Distance from far wall (mm)	Isokinetic Flowrate (L/min)	Meter Inlet Temp. (°C)	Meter Outlet Temp. (°C)	Impinger Train Outlet Temp (°C)	Flowrate Attained (Y/N)
1/1	0:07:00	33	12.2	24.0	25.0		Yes
1/2	0:14:00	111	11.5	27.0	25.0		Yes
1/3	0:21:00	225	13.8	28.0	25.0		Yes
1/4	0:28:00	535	12.9	28.0	25.0		Yes
1/5	0:35:00	649	12.2	29.0	24.0		Yes
1/6	0:42:00	727	12.7	29.0	24.0		Yes
2/1	0:49:00	33	9.1	31.0	24.0		Yes
2/2	0:56:00	111	9.8	31.0	24.0		Yes
2/3	1:03:00	225	8.4	31.0	24.0		Yes
2/4	1:10:00	535	12.2	31.0	24.0		Yes
2/5	1:17:00	649	10.6	31.0	24.0		Yes
2/6	1:24:00	727	12.9	31.0	24.0		Yes
Averages				29.3	24.3	no result	

Meter Finish: 5541.0470

Time Finish: 11:46

Total Condensate collected: -10 ml

Silica gel No(s) used: 110

STACK ANALYSIS

SAMPLING OF HAZARDOUS SUBSTANCES (METALS)

Date: 22-May-19

Client: Liberty Recycling Hexham

AECOM's Project No: 60493017

Stack Description No.: Shredder Stack

Sample Nozzle No.:	XI	Sample Nozzle Area (A _n):	3.72	x 10 ⁻⁵ m ²
--------------------	----	---------------------------------------	------	-----------------------------------

Sampling Port No.: 1 to 2 Thimble No: 0

Page No: 1 of 1 Blank thimble No:

Leak Check (Pre-Sampling)

Meter start: 22179.9556 Meter finish: 22179.9556 Meter start: 22181.2742 Meter finish: 22181.2742

Time start: 9:57 Time finish: 9:58 Time start: 11:50 Time finish: 11:51

Therefore, leakage rate = no leak L/min Therefore, leakage rate = no leak L/min

(>0.1 l/min. is unacceptable)

Repeat:

Repeat:

Comments:

Comments:

Sampling Record Table

Barometric Pressure: 1028 hPa (start); 1028 hPa (finish)

Meter start: 22179.9576 Time start: 10:22

Meter correction factor (GMf) : 1.0137

Sampling Position No.	Stopwatch Time at Sampling Position	Distance from far wall (mm)	Isokinetic Flowrate (L/min)	Meter Inlet Temp. (°C)	Meter Outlet Temp. (°C)	Impinger Train Outlet Temp (°C)	Flowrate Attained (Y/N)
1/1	0:07:00	33	16.1	24.0	20.0		Yes
1/2	0:14:00	111	15.2	28.0	21.0		Yes
1/3	0:21:00	225	18.2	29.0	22.0		Yes
1/4	0:28:00	535	17.0	29.0	23.0		Yes
1/5	0:35:00	649	16.1	33.0	24.0		Yes
1/6	0:42:00	727	16.8	33.0	25.0		Yes
2/1	0:49:00	33	12.0	35.0	26.0		Yes
2/2	0:56:00	111	12.9	35.0	27.0		Yes
2/3	1:03:00	225	11.0	35.0	27.0		Yes
2/4	1:10:00	535	16.1	35.0	27.0		Yes
2/5	1:17:00	649	14.0	35.0	27.0		Yes
2/6	1:24:00	727	17.0	34.0	26.0		Yes
Averages				32.1	24.6	no result	

Meter Finish:	22181.2728	Time Finish:	11:46
---------------	------------	--------------	-------

Water Finish:	22704:2725	Water Finish:	22704:2725
Total Condensate collected:	0 ml	Silica gel No(s) used:	42

Q4AN(EV)-332-FM31

Date: 22-May-19
Client: Liberty Recycling Hexham
AECOM's Project No: 60493017
Stack/Duct Description: Shredder Stack
Test 1: Fine Particulate (PM10)
Test 2: Total Particulate
Test 3: Hazardous Substances (Metals)

Static Pressure (Dwyer) (Pa): kPa
 Static Pressure (U-tube, if required) : -3 mm
 Absolute pressure in stack (hPa) : 1025.71 hPa

STACK ANALYSIS - FINAL CALCULATIONS

Fine Particulate (PM10)

(Calculations performed in accordance with relevant test method as defined on cover page)

Date: 22-May-19 Client: Liberty Recycling Hexham
AECOM's Project No: 60493017 Stack/Duct Description: Shredder Stack

(A) Sample gas volume at standard conditions

Metered volume (MV ₃):	1.1659 m ³	Average barometric pressure (P _{BARO}):	1028 hPa
Average gas meter temp. (T _{M,2}):	25.7 °C	Average pressure at meter (P _{M,2}):	1028.00 hPa
	298.9 K		

Sample gas volume (MV₄)_i (0°C, dry gas, 1 atm pressure): 1.0812 m³

(B) PM10 concentration at standard conditions

Blank thimble No.:	0	Blank weight:	g
Thimble No. used:	N23	PM10 Weight	0.0088 g
Final PM10 Weight (Mp1):	0.00880 g		
PM10 Concentration (C1):	=M _{p1} /MV ₄ =	0.0081 g/m ³ (0°C, dry gas, 1atm pressure)	

;and C₂ = 8.1 mg/m³ (0°C, dry gas, 1atm pressure)

CO₂ Basis 12 %

Average CO₂%: 0.0 %

Therefore, C_c: = C_a x 12/CO₂% = 0.0081 g/m³ (0°C, dry gas, 1atm pressure, 12% CO₂)

;and C_{c1} = 8.1 mg/m³ (0°C, dry gas, 1atm pressure, 12% CO₂)

O₂ Basis 7 %

Average O₂%: 20.9 %

Therefore, C_b: =C_a x (21 - O_{2ref} %)/(21 - O_{2mea} %) 1.1 g/m³ (0°C, dry gas, 1atm pressure, 7% O₂)

;and C_{b1} = 1100 mg/m³ (0°C, dry gas, 1atm pressure, 7% O₂)

(C) Moisture content

Silica Gel Number: 118

V_v = 17.1 g (from laboratory report) V_w = -10 mL (=grams) (recorded on Laboratory Form 108)

Volume of Water Vapour Condensed (V_{wc(std)}) = -0.0133

Volume of Water Vapour Condensed (V_{wsg(std)}) = 0.0228

Therefore, B_{ws} = $\frac{(V_{wc(std)} + V_{wsg(std)})}{(V_{wc(std)} + V_{wsg(std)} + V_{m(std)})}$

B_{ws} = 0.20 %

ANZ

Emission Measurement Calculations Spreadsheet

Q4AN(EV)-332-FM31

STACK ANALYSIS - FINAL CALCULATIONS CONTINUED

Fine Particulate (PM10)

(D) Gas Composition and Density (Re-calculation)

(i) Initial gas density for sampling:	1.29 kg/m ³ (from Laboratory Form 107)
(ii) Re-calculated gas density based on moisture content in (c):	1.29 kg/m ³ (0°C, wet, 1 atm pressure) 1.29 kg/m ³ (0°C, dry, 1 atm pressure)
(iii) Gas density at stack conditions =	(ii) x $\frac{(273.2)}{(273.2+T_s)} \times \frac{(P_s)}{(1013.25)}$
=	1.205 kg/m ³ (stack conditions, wet)

(E) Gas Velocities

(i) Average of pre-sampling velocities:	6.61 m/s
(ii) Average of post-sampling velocities:	6.56 m/s
(iii) Average of while-sampling velocities:	N/A m/s
(iv) Overall average of pre-sampling and post-sampling velocities (Vs):	6.58 m/s (stack conditions, wet) N/A m/s (stack conditions, wet)
(Note: (Vs) is from all individual data, not from (i) and (ii) alone.)	

(F) Volumetric Flowrates (Reference Method US-EPA Method 2, NSW-EPA TM-2)

Qstack =	Vs x A =	2.98 m ³ /s (stack conditions)
Qstd =	Qstack x $\frac{P_s}{(P_{std})} \times \frac{(T_{std})}{(T_s)} \times \frac{(100 - B_w)}{100}$	
Qstd =	2.8 m ³ /s (0°C, dry gas, 1 atm pressure)	

(G) Mass Emission Rate

Rm =	C _{1a} x Qstd =	0.023 g/s (0°C, dry gas, 1 atm pressure)
	=	23 mg/s (0°C, dry gas, 1 atm pressure)

Emission Measurement Calculations Spreadsheet

Q4AN(EV)-332-FM31

STACK ANALYSIS - FINAL CALCULATIONS

Total Particulate

(Calculations performed in accordance with relevant test method as defined on cover page)

Date: 22-May-19

Client: Liberty Recycling Hexham

AECOM's Project No:

60493017 Stack/Duct Description: Shredder Stack

(A) Sample gas volume at standard conditions

Metered volume (MV ₃):	0.9834 m ³	Average barometric pressure (P _{BARO}):	1028 hPa
Average gas meter temp. (T _{M,2}):	26.8 °C	Average pressure at meter (P _{M,2}):	1028.00 hPa
	300.0 K		

Sample gas volume (MV₄); (0°C, dry gas, 1 atm pressure):

0.9086 m³

(B) Total Particulate concentration at standard conditions

Blank thimble No.:

Blank weight:

Thimble No. used: T30

Total Particulate Weight

Final Total Particulate Weight (Mp1):

0.01970 g

Total Particulate Concentration (C1):

 $= M_{p1} / MV_4 =$

0.0197 g

0.022 g/m³ (0°C, dry gas, 1atm pressure);and C₂ =22 mg/m³ (0°C, dry gas, 1atm pressure)CO₂ Basis 12 %Average CO₂%: 0.0 %Therefore, C_c: $= C_a \times 12 / CO_2\% =$ 0.022 g/m³ (0°C, dry gas, 1atm pressure, 12% CO₂);and C_{c1} =22 mg/m³ (0°C, dry gas, 1atm pressure, 12% CO₂)O₂ Basis 7 %Average O₂%: 20.9 %Therefore, C_b: $= C_a \times (21 - O_{2ref}\%) / (21 - O_{2mea}\%)$ 3.1 g/m³ (0°C, dry gas, 1atm pressure, 7% O₂);and C_{b1} =3100 mg/m³ (0°C, dry gas, 1atm pressure, 7% O₂)

(C) Moisture content

Silica Gel Number: 110

V_v = 16.3 g (from laboratory report)V_w =-10 mL (=grams)
(recorded on Laboratory Form 108)Volume of Water Vapour Condensed (V_{wc(std)}) = -0.0133Volume of Water Vapour Condensed (V_{wsg(std)}) = 0.0218Therefore, B_{ws} =
$$\frac{(V_{wc(std)} + V_{wsg(std)})}{(V_{wc(std)} + V_{wsg(std)} + V_{m(std)})}$$
B_{ws} = 0.20 %

ANZ

Emission Measurement Calculations Spreadsheet

Q4AN(EV)-332-FM31

STACK ANALYSIS - FINAL CALCULATIONS CONTINUED

Total Particulate

(D) Gas Composition and Density (Re-calculation)

- (i) Initial gas density for sampling: 1.29 kg/m³ (from Laboratory Form 107)
- (ii) Re-calculated gas density based on moisture content in (c):
 1.29 kg/m³ (0°C, wet, 1 atm pressure)
 1.29 kg/m³ (0°C, dry, 1 atm pressure)
- (iii) Gas density at stack conditions = (ii) x $\frac{(273.2)}{(273.2+T_s)} \times \frac{(P_s)}{(1013.25)}$
- = 1.205 kg/m³ (stack conditions, wet)

(E) Gas Velocities

- (i) Average of pre-sampling velocities: 6.61 m/s
- (ii) Average of post-sampling velocities: 6.56 m/s
- (iii) Average of while-sampling velocities: N/A m/s
- (iv) Overall average of pre-sampling and post-sampling velocities (Vs):
 6.58 m/s (stack conditions, wet)
 N/A m/s (stack conditions, wet)
- (Note: (Vs) is from all individual data, **not** from (i) and (ii) alone.)

(F) Volumetric Flowrates (Reference Method US-EPA Method 2, NSW-EPA TM-2)

$$Q_{stack} = V_s \times A = 2.98 \text{ m}^3/\text{s} \text{ (stack conditions)}$$

$$Q_{std} = Q_{stack} \times \frac{P_s}{(P_{std})} \times \frac{(T_{std})}{(T_s)} \times \frac{(100 - B_w)}{100}$$

$$Q_{std} = 2.8 \text{ m}^3/\text{s} \text{ (0°C, dry gas, 1 atm pressure)}$$

(G) Mass Emission Rate

$$R_m = C_{1a} \times Q_{std} = 0.061 \text{ g/s (0°C, dry gas, 1 atm pressure)}$$

$$= 61 \text{ mg/s (0°C, dry gas, 1 atm pressure)}$$

Emission Measurement Calculations Spreadsheet

STACK ANALYSIS - FINAL CALCULATIONS

Hazardous Substances (Metals)

(Calculations performed in accordance with relevant test method as defined on cover page)

Date: 22-May-19

Client: Liberty Recycling Hexham

AECOM's Project No:

60493017 Stack/Duct Description: Shredder Stack

(A) Sample gas volume at standard conditions

Metered volume (MV ₃):	1.3332 m ³	Average barometric pressure (P _{BARO}):	1028 hPa
Average gas meter temp. (T _{M,2}):	28.3 °C	Average pressure at meter (P _{M,2}):	1028.00 hPa
	301.5 K		
Sample gas volume (MV ₄); (0°C, dry gas, 1 atm pressure):	1.2256 m ³		

(B) Metals concentration at standard conditions

Blank thimble No.:		Blank weight:	g
Thimble No. used:	0	Metals Weight:	0.000218 g
Final Metals Weight (Mp1):	0.00022 g		
Metals Concentration (C1):	=M _{p1} /MV ₄ =	0.00018 g/m ³ (0°C, dry gas, 1atm pressure)	

;and C₂ =0.18 mg/m³ (0°C, dry gas, 1atm pressure)CO₂ Basis 12 %Average CO₂%: 0.0 %Therefore, C_c: = C_a x 12/CO₂% =0.00018 g/m³ (0°C, dry gas, 1atm pressure, 12% CO₂);and C_{c1} =0.18 mg/m³ (0°C, dry gas, 1atm pressure, 12% CO₂)O₂ Basis 7 %Average O₂%: 20.9 %Therefore, C_b: = C_a x (21 - O_{2ref}%)/(21 - O_{2mea}%)0.025 g/m³ (0°C, dry gas, 1atm pressure, 7% O₂);and C_{b1} =25 mg/m³ (0°C, dry gas, 1atm pressure, 7% O₂)

(C) Moisture content

Silica Gel Number: 42

V_v = 8.2 g (from laboratory report)V_w =

0 mL (=grams)

Volume of Water Vapour Condensed (V_{wc(std)}) = 0.0000

(recorded on

Volume of Water Vapour Condensed (V_{wsg(std)}) = 0.0109

Laboratory Form

108)

Therefore, B_{ws} =
$$\frac{(V_{wc(std)} + V_{wsg(std)})}{(V_{wc(std)} + V_{wsg(std)} + V_{m(std)})}$$

B_{ws} = 0.20 %

ANZ

Emission Measurement Calculations Spreadsheet

Q4AN(EV)-332-FM31

STACK ANALYSIS - FINAL CALCULATIONS CONTINUED

Hazardous Substances (Metals)

(D) Gas Composition and Density (Re-calculation)

- (i) Initial gas density for sampling: 1.29 kg/m³ (from Laboratory Form 107)
- (ii) Re-calculated gas density based on moisture content in (c):
 1.29 kg/m³ (0°C, wet, 1 atm pressure)
 1.29 kg/m³ (0°C, dry, 1 atm pressure)
- (iii) Gas density at stack conditions = (ii) x $\frac{(273.2)}{(273.2+T_s)}$ x $\frac{(P_s)}{(1013.25)}$
- = 1.205 kg/m³ (stack conditions, wet)

(E) Gas Velocities

- (i) Average of pre-sampling velocities: 6.61 m/s
- (ii) Average of post-sampling velocities: 6.56 m/s
- (iii) Average of while-sampling velocities: N/A m/s
- (iv) Overall average of pre-sampling and post-sampling velocities (Vs): 6.58 m/s (stack conditions, wet)
 N/A m/s (stack conditions, wet)
- (Note: (Vs) is from all individual data, **not** from (i) and (ii) alone.)

(F) Volumetric Flowrates (Reference Method US-EPA Method 2, NSW-EPA TM-2)

$$Q_{\text{stack}} = V_s \times A = 2.98 \text{ m}^3/\text{s} \text{ (stack conditions)}$$

$$Q_{\text{std}} = Q_{\text{stack}} \times \frac{P_s}{(P_{\text{std}})} \times \frac{(T_{\text{std}})}{(T_s)} \times \frac{(100 - B_w)}{100}$$

$$Q_{\text{std}} = 2.8 \text{ m}^3/\text{s} \text{ (0°C, dry gas, 1 atm pressure)}$$

(G) Mass Emission Rate

$$R_m = C_{1a} \times Q_{\text{std}} = 0.0005 \text{ g/s (0°C, dry gas, 1 atm pressure)}$$

$$= 0.5 \text{ mg/s (0°C, dry gas, 1 atm pressure)}$$

Emission Measurement Calculations Spreadsheet

EMISSION MONITORING RESULTS, SHREDDER STACK LIBERTY RECYCLING HEXHAM 22-May-19 FINE PARTICULATE (PM10) TOTAL PARTICULATE HAZARDOUS SUBSTANCES (METALS)		
Sampling Conditions:		
Stack internal diameter at test location	760 mm	
Stack gas temperature (average)	23.0 °C	296.2 K
Stack pressure (average)	1026 hPa	
Stack gas velocity (average, stack conditions)	6.6 m/s	
Stack gas flowrate (stack conditions)	3 m ³ /s	
Stack gas flowrate (0°C, dry gas, 1 atm pressure)	2.8 m ³ /s	
Fine Particulate (PM10) Testing		
Test Period	10:22	- 11:46
Fine Particulate (PM10) Mass	8.8 mg	
Gas Volume Sampled	1.08 m ³	
Fine Particulate (PM10) Emission*1	8.1 mg/m ³	
Fine Particulate (PM10) Mass Emission Rate*2	23 mg/s	
Regulatory Limit	N/A mg/m ³	
Total Particulate Testing		
Test Period	10:22	- 11:46
Total Particulate Mass	19.7 mg	
Gas Volume Sampled	0.909 m ³	
Total Particulate Emission*1	22 mg/m ³	
Total Particulate Mass Emission Rate*2	61 mg/s	
Regulatory Limit	100 mg/m ³	
Hazardous Substances (Metals) Testing		
Test Period	10:22	- 11:46
Hazardous Substances (Metals) Mass	0.218 mg	
Gas Volume Sampled	1.23 m ³	
Hazardous Substances (Metals) Emission*1	0.18 mg/m ³	
Hazardous Substances (Metals) Mass Emission Rate*2	0.5 mg/s	
Regulatory Limit	N/A mg/m ³	
Moisture Content (%)	0.2	
Gas Density (dry at 1 atmosphere)	1.29 kg/m ³	
Dry Molecular Weight	28.8 g/g-mole	

Notes *1 Emission concentration at Standard conditions of 0°C, 1 atm, dry gas

*2 Mass emission rate determined from pre and post test sampling flow measurements and the respective test moisture content. See Q_{std} in field sheets and final calculations "Stack Analysis - Final Calculations" for each test.

Appendix B

Laboratory Results
(8 pages)

Appendix B Laboratory Results (8 pages)

STACK EMISSION - PARTICULATES REPORT

Origin: AECOM - Newcastle

Project: 60493017

Report : 18854-0-P

Page 1 of 1

Description : Stack Emission Samples

Received: 23-May-19

Date : 28-May-19

Report To : Cye Buckland

17 Warabrook Blvd, Warabrook NSW 2304

Copy to: FILE

Thimble ID		Volume (mL)	Total Particulate Matter (g)
N23	Thimble	-	0.0088
T30	Thimble	-	0.0197

STACK EMISSION - MOISTURE REPORT

Origin: AECOM - Newcastle
Project: 60493017

Report : 18854-0-M Page 1 of 1

Description : Stack Emission Samples
Received: 23-May-19

Date : 28-May-19

Report To : Cye Buckland
17 Warabrook Blvd, Warabrook NSW 2304

Copy to: FILE

Jar ID	Moisture (g)
110	16.3
118	17.1
42	8.2

CLIENT DETAILS

Contact **Cye Buckland**
 Client **AECOM Australia Pty Ltd**
 Address **17 Warabrook Boulevard
 Warabrook
 SYDNEY NSW 2304**

Telephone **02 8295 3600**
 Facsimile **02 8934 0001**
 Email **cye.buckland@aecom.com**

Project **60493017/4.1**
 Order Number **60493017/4.1**
 Samples **12**

LABORATORY DETAILS

Manager **Adam Atkinson**
 Laboratory **SGS Melbourne EH&S**
 Address **10/585 Blackburn Road
 Notting Hill Victoria 3168**


Telephone **+61395743200**
 Facsimile **+61395743399**
 Email **Au.SampleReceipt.Melbourne@sgs.com**

SGS Reference **ME310641 R0**
 Date Received **24 May 2019**
 Date Reported **05 Jun 2019**

COMMENTS

Accredited for compliance with ISO/IEC 17025 - Testing. NATA accredited laboratory 2562(14420).

SIGNATORIES



Weiming Dai
Inorganic Supervisor



Ryan Zhang
Team Leader



ANALYTICAL REPORT

ME310641 R0

Parameter	Sample Number		ME310641.001	ME310641.002	ME310641.003	ME310641.004
	Sample Matrix		Filter	Filter	Impinger	Impinger
	Sample Date		22 May 2019	22 May 2019	22 May 2019	22 May 2019
	Sample Name		Metals 1	Metal 12	Metals 3	Metals 4
Units	LOR					

Metals in Filters M29 ETC MA-1400.FL.M29.02 USEPA M29 Method: EPA29_FILT Tested: 29/5/2019

Sb	µg total	0.05	0.21	0.07	-	-
As	µg total	0.05	0.69	0.66	-	-
Be	µg total	0.05	0.06	0.07	-	-
Cd	µg total	0.05	2.1	<0.05	-	-
Cr	µg total	0.05	2.5	2.4	-	-
Co	µg total	0.05	0.09	<0.05	-	-
Cu	µg total	0.05	0.81	<0.05	-	-
Pb	µg total	0.05	6.0	1.2	-	-
Mg	µg total	0.05	340	330	-	-
Mn	µg total	0.05	3.7	1.6	-	-
Hg	µg total	0.05	<0.05	<0.05	-	-
Ni	µg total	0.05	0.87	0.24	-	-
Se	µg total	0.05	0.17	<0.05	-	-
Tl	µg total	0.05	<0.05	<0.05	-	-
Sn	µg total	0.05	0.78	0.11	-	-
V	µg total	0.25	0.83	1.0	-	-
Zn	µg total	0.05	7800	7900	-	-

Metals in Impingers M29 ETC MA-1400.IMP.M29.06 (ug total) Method: EPA29_METIMP Tested: 4/6/2019

Sb	µg total	0.1	-	-	1.3	1.3
As	µg total	0.1	-	-	0.2	0.2
Be	µg total	0.1	-	-	<0.1	<0.1
Cd	µg total	0.1	-	-	0.7	0.9
Cr	µg total	0.1	-	-	1.1	4.5
Co	µg total	0.1	-	-	0.4	6.4
Cu	µg total	0.1	-	-	9.8	3.1
Pb	µg total	0.1	-	-	110	2.5
Mg	µg total	0.1	-	-	55	5.6
Mn	µg total	0.1	-	-	13	24
Hg	µg total	0.1	-	-	<0.1	<0.1
Ni	µg total	0.1	-	-	2.7	39
Se	µg total	0.1	-	-	0.3	<0.1
Tl	µg total	0.1	-	-	<0.1	<0.1
Sn	µg total	0.1	-	-	0.8	0.4
V	µg total	0.1	-	-	0.6	0.9
Zn	µg total	0.1	-	-	580	32
Sample Volume*	mL	-	-	-	94	300



ANALYTICAL REPORT

ME310641 R0

Parameter	Units	LOR	Sample Number Sample Matrix Sample Date Sample Name	ME310641.005 Impinger 22 May 2019 Metals 8A	ME310641.006 Impinger 22 May 2019 Metals 9	ME310641.007 Impinger 22 May 2019 Metals 5A	ME310641.008 Impinger 22 May 2019 Metals 5C
-----------	-------	-----	--	--	---	--	--

Metals in Filters M29 ETC MA-1400.FL.M29.02 USEPA M29 Method: EPA29_FILT Tested: 30/5/2019

Sb	µg total	0.05	-	-	-	-
As	µg total	0.05	-	-	-	-
Be	µg total	0.05	-	-	-	-
Cd	µg total	0.05	-	-	-	-
Cr	µg total	0.05	-	-	-	-
Co	µg total	0.05	-	-	-	-
Cu	µg total	0.05	-	-	-	-
Pb	µg total	0.05	-	-	-	-
Mg	µg total	0.05	-	-	-	-
Mn	µg total	0.05	-	-	-	-
Hg	µg total	0.05	-	-	-	-
Ni	µg total	0.05	-	-	-	-
Se	µg total	0.05	-	-	-	-
Tl	µg total	0.05	-	-	-	-
Sn	µg total	0.05	-	-	-	-
V	µg total	0.25	-	-	-	-
Zn	µg total	0.05	-	-	-	-

Metals in Impingers M29 ETC MA-1400.IMP.M29.06 (ug total) Method: EPA29_METIMP Tested: 29/5/2019

Sb	µg total	0.1	0.4	0.6	-	-
As	µg total	0.1	<0.1	0.2	-	-
Be	µg total	0.1	<0.1	<0.1	-	-
Cd	µg total	0.1	<0.1	<0.1	-	-
Cr	µg total	0.1	<0.1	0.4	-	-
Co	µg total	0.1	<0.1	<0.1	-	-
Cu	µg total	0.1	<0.1	<0.1	-	-
Pb	µg total	0.1	<0.1	<0.1	-	-
Mg	µg total	0.1	<0.1	1.2	-	-
Mn	µg total	0.1	0.2	1.5	-	-
Hg	µg total	0.1	<0.1	<0.1	<0.1	<0.1
Ni	µg total	0.1	<0.1	0.2	-	-
Se	µg total	0.1	0.2	0.5	-	-
Tl	µg total	0.1	<0.1	<0.1	-	-
Sn	µg total	0.1	<0.1	0.2	-	-
V	µg total	0.1	0.7	1.3	-	-
Zn	µg total	0.1	0.2	0.7	-	-
Sample Volume*	mL	-	310	210	98	300



ANALYTICAL REPORT

ME310641 R0

			Sample Number	ME310641.009	ME310641.010	ME310641.011	ME310641.012
			Sample Matrix	Impinger	Impinger	KMnO4	KMnO4
			Sample Date	22 May 2019	22 May 2019	22 May 2019	22 May 2019
			Sample Name	Metals 8B	Metals 11	Metals 5B	Metals 10
Parameter	Units	LOR					

Metals in Filters M29 ETC MA-1400.FL.M29.02 USEPA M29 Method: EPA29_FILT Tested: 30/5/2019

Sb	µg total	0.05	-	-	-	-
As	µg total	0.05	-	-	-	-
Be	µg total	0.05	-	-	-	-
Cd	µg total	0.05	-	-	-	-
Cr	µg total	0.05	-	-	-	-
Co	µg total	0.05	-	-	-	-
Cu	µg total	0.05	-	-	-	-
Pb	µg total	0.05	-	-	-	-
Mg	µg total	0.05	-	-	-	-
Mn	µg total	0.05	-	-	-	-
Hg	µg total	0.05	-	-	-	-
Ni	µg total	0.05	-	-	-	-
Se	µg total	0.05	-	-	-	-
Tl	µg total	0.05	-	-	-	-
Sn	µg total	0.05	-	-	-	-
V	µg total	0.25	-	-	-	-
Zn	µg total	0.05	-	-	-	-

Metals in Impingers M29 ETC MA-1400.IMP.M29.06 (ug total) Method: EPA29_METIMP Tested: 29/5/2019

Sb	µg total	0.1	-	-	-	-
As	µg total	0.1	-	-	-	-
Be	µg total	0.1	-	-	-	-
Cd	µg total	0.1	-	-	-	-
Cr	µg total	0.1	-	-	-	-
Co	µg total	0.1	-	-	-	-
Cu	µg total	0.1	-	-	-	-
Pb	µg total	0.1	-	-	-	-
Mg	µg total	0.1	-	-	-	-
Mn	µg total	0.1	-	-	-	-
Hg	µg total	0.1	<0.1	<0.1	0.1	<0.1
Ni	µg total	0.1	-	-	-	-
Se	µg total	0.1	-	-	-	-
Tl	µg total	0.1	-	-	-	-
Sn	µg total	0.1	-	-	-	-
V	µg total	0.1	-	-	-	-
Zn	µg total	0.1	-	-	-	-
Sample Volume*	mL	-	200	250	400	100

MB blank results are compared to the Limit of Reporting

LCS and MS spike recoveries are measured as the percentage of analyte recovered from the sample compared the the amount of analyte spiked into the sample.

DUP and MSD relative percent differences are measured against their original counterpart samples according to the formula : *the absolute difference of the two results divided by the average of the two results as a percentage*. Where the DUP RPD is 'NA' , the results are less than the LOR and thus the RPD is not applicable.

Metals in Filters M29 ETC MA-1400.FL.M29.02 USEPA M29 Method: EPA29_FILTER

Parameter	QC Reference	Units	LOR	MB	LCS %Recovery
Sb	LB026810	µg total	0.05	<0.05	105%
As	LB026810	µg total	0.05	<0.05	101%
Be	LB026810	µg total	0.05	<0.05	99%
Cd	LB026810	µg total	0.05	<0.05	100%
Cr	LB026810	µg total	0.05	<0.05	104%
Co	LB026810	µg total	0.05	<0.05	103%
Cu	LB026810	µg total	0.05	<0.05	110%
Pb	LB026810	µg total	0.05	<0.05	105%
Mg	LB026810	µg total	0.05	<0.05	110%
Mn	LB026810	µg total	0.05	<0.05	104%
Hg	LB026810	µg total	0.05	<0.05	98%
Ni	LB026810	µg total	0.05	<0.05	104%
Se	LB026810	µg total	0.05	<0.05	99%
Tl	LB026810	µg total	0.05	<0.05	103%
Sn	LB026810	µg total	0.05	<0.05	102%
V	LB026810	µg total	0.25	<0.25	105%
Zn	LB026810	µg total	0.05	<0.05	104%

Metals in Impingers M29 ETC MA-1400.IMP.M29.06 (ug total) Method: EPA29_METIMP

Parameter	QC Reference	Units	LOR	MB	LCS %Recovery
Sb	LB026812	µg total	0.1	<0.1	103%
As	LB026812	µg total	0.1	<0.1	98%
Be	LB026812	µg total	0.1	<0.1	93%
Cd	LB026812	µg total	0.1	<0.1	97%
Cr	LB026812	µg total	0.1	<0.1	107%
Co	LB026812	µg total	0.1	<0.1	113%
Cu	LB026812	µg total	0.1	<0.1	110%
Pb	LB026812	µg total	0.1	<0.1	106%
Mg	LB026812	µg total	0.1	<0.1	107%
Mn	LB026812	µg total	0.1	<0.1	105%
Hg	LB026812	µg total	0.1	<0.1	
Ni	LB026812	µg total	0.1	<0.1	108%
Se	LB026812	µg total	0.1	<0.1	96%
Tl	LB026812	µg total	0.1	<0.1	104%
Sn	LB026812	µg total	0.1	<0.1	101%
V	LB026812	µg total	0.1	<0.1	107%
Zn	LB026812	µg total	0.1	<0.1	105%
Sample Volume*	LB026812	mL	-	1.0	NA

METHOD

METHODOLOGY SUMMARY

EPA 29

Analysis of acid-leachable metals by Inductively Coupled Plasma-Mass Spectrometer (ICP-MS). This method is based on USEPA 3051A, USEPA M29, and USEPA 6020A. Filters are digested using the appropriate sample preparation methods. A representative sample is extracted in concentrated acid using microwave heating by the CEM -MarsXPress (with Built-in USEPA method) Microwave Digestion system. The sample and acid are placed in a microwave vessel (TFM), which is then capped and heated in the microwave unit. After cooling, the vessel contents are diluted with DI water, then filtered/settled/centrifuged and analysed by ICP MS.

EPA29

This method covers the analysis of acid-leachable metals by Inductively Coupled Plasma-Mass Spectrometer (ICP-MS). This method is based on USEPA M29, USEPA 3015A and USEPA 6020A. Prior to analysis, samples are be solubilised or digested using the appropriate sample preparation methods.

FOOTNOTES

IS	Insufficient sample for analysis.	LOR	Limit of Reporting
LNR	Sample listed, but not received.	↑↓	Raised or Lowered Limit of Reporting
*	NATA accreditation does not cover the performance of this service.	QFH	QC result is above the upper tolerance
**	Indicative data, theoretical holding time exceeded.	QFL	QC result is below the lower tolerance
		-	The sample was not analysed for this analyte
		NVL	Not Validated

Unless it is reported that sampling has been performed by SGS, the samples have been analysed as received. Solid samples expressed on a dry weight basis.

Where "Total" analyte groups are reported (for example, Total PAHs, Total OC Pesticides) the total will be calculated as the sum of the individual analytes, with those analytes that are reported as <LOR being assumed to be zero. The summed (Total) limit of reporting is calculated by summing the individual analyte LORs and dividing by two. For example, where 16 individual analytes are being summed and each has an LOR of 0.1 mg/kg, the "Totals" LOR will be 1.6 / 2 (0.8 mg/kg). Where only 2 analytes are being summed, the "Total" LOR will be the sum of those two LORs.

Some totals may not appear to add up because the total is rounded after adding up the raw values.

If reported, measurement uncertainty follow the ± sign after the analytical result and is expressed as the expanded uncertainty calculated using a coverage factor of 2, providing a level of confidence of approximately 95%, unless stated otherwise in the comments section of this report.

Results reported for samples tested under test methods with codes starting with ARS-SOP, radionuclide or gross radioactivity concentrations are expressed in becquerel (Bq) per unit of mass or volume or per wipe as stated on the report. Becquerel is the SI unit for activity and equals one nuclear transformation per second.

Note that in terms of units of radioactivity:

- 1 Bq is equivalent to 27 pCi
- 37 MBq is equivalent to 1 mCi

For results reported for samples tested under test methods with codes starting with ARS-SOP, less than (<) values indicate the detection limit for each radionuclide or parameter for the measurement system used. The respective detection limits have been calculated in accordance with ISO 11929.

The QC and MU criteria are subject to internal review according to the SGS QAQC plan and may be provided on request or alternatively can be found here: www.sgs.com.au/pv.sgsvr/en-gb/environment.

This document is issued by the Company under its General Conditions of Service accessible at www.sgs.com/en/Terms-and-Conditions.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client only. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

This report must not be reproduced, except in full.

