

# 1st Quarter Emissions Testing Report 2019

Liberty Recycling Hexham



NATA ACCREDITATION No. 2778 (14391)

Accredited for compliance with ISO/IEC 17025 – Testing

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

This document may not be reproduced except in full.

# 1st Quarter Emissions Testing Report 2019

Liberty Recycling Hexham

Client: Liberty Recycling Pty Ltd

ABN: 28 002 707 262

Prepared by

**AECOM Australia Pty Ltd**

17 Warabrook Boulevard, Warabrook NSW 2304, PO Box 73, Hunter Region MC NSW 2310, Australia  
T +61 2 4911 4900 F +61 2 4911 4999 [www.aecom.com](http://www.aecom.com)

ABN 20 093 846 925

03-May-2019

Job No.: 60493017

AECOM in Australia and New Zealand is certified to ISO9001, ISO14001 AS/NZS4801 and OHSAS18001.

© AECOM Australia Pty Ltd (AECOM). All rights reserved.

AECOM has prepared this document for the sole use of the Client and for a specific purpose, each as expressly stated in the document. No other party should rely on this document without the prior written consent of AECOM. AECOM undertakes no duty, nor accepts any responsibility, to any third party who may rely upon or use this document. This document has been prepared based on the Client's description of its requirements and AECOM's experience, having regard to assumptions that AECOM can reasonably be expected to make in accordance with sound professional principles. AECOM may also have relied upon information provided by the Client and other third parties to prepare this document, some of which may not have been verified. Subject to the above conditions, this document may be transmitted, reproduced or disseminated only in its entirety.

## Quality Information

Document 1st Quarter Emissions Testing Report 2019

Ref 60493017

Date 09-April-2019


Prepared by Colin Clarke

Reviewed by Paul Wenta

AECOM Approved Signatory Chad Whitburn

  
\_\_\_\_\_

### Revision History

Rev	Revision Date	Details	Authorised	
			Name/Position	Signature
0	3-May-2019	Report for Issue	Chad Whitburn Associate Director - Compliance Services	

## Table of Contents

1.0	Introduction	1
2.0	Sampling Plane Requirements	2
3.0	Methodology	3
3.1	NATA Accredited Methods	3
3.2	Equipment Calibration	3
4.0	Sampling Location	4
4.1	Sampling Location Summary	4
5.0	Results	5
Appendix A		
	Field Sheets (19 pages)	A
Appendix B		
	Laboratory Results (8 pages)	B

## List of Tables

Table 1	Criteria for Selection of Sampling Planes (AS 4323.1)	2
Table 2	AECOM NATA Endorsed Methods	3
Table 3	Sampling Location Summary	4
Table 4	Shredder Baghouse Emission Results Summary, 14 March 2019	5
Table 5	Fine Particulate (PM <sub>10</sub> ), Total Particulate and Hazardous Substance (Metals) Results, 14 March 2019	6
Table 6	Hazardous Substances (Metals) Elemental Analysis Results, 14 March 2019	7

## 1.0 Introduction

AECOM was appointed by Liberty Recycling Pty Ltd to conduct a series of measurements to determine air emissions from the Shredder Baghouse Stack (EPL Point 1) at the Hexham facility. Measurements were required for NSW EPA licence compliance (EPL No. 5345).

Testing was undertaken on 14 March 2019 to investigate emission concentrations for the following parameters:

- Fine Particulates (PM<sub>10</sub>);
- Total Particulate (TP); and
- Hazardous Substances (Metals) including Lead and Mercury.

Laboratory analysis was undertaken by the following laboratories which hold NATA accreditation for the specified tests:

- Steel River Testing, laboratory NATA accreditation number 18079, performed the following analysis detailed in report number 18314-0-M & 18314-0-P:
  - Total Particulate (TP);
  - Fine Particulates (PM<sub>10</sub>); and
  - Moisture.
- SGS Australia Pty Ltd, NATA accreditation number 2562, performed the following analysis detailed in report number ME309936 R0:
  - Hazardous Substances (Metals).

## 2.0 Sampling Plane Requirements

The criteria for sampling planes are specified in AS 4323.1-1995 (R2014).

**Table 1 Criteria for Selection of Sampling Planes (AS 4323.1)**

Type of flow disturbance	Minimum distance upstream from disturbance, diameters (D)	Minimum distance downstream from disturbance, diameters (D)
Bend, connection, junction, direction change	>2D	>6D
Louvre, butterfly damper (partially closed or closed)	>3D	>6D
Axial fan	>3D	>8D (see Note)
Centrifugal fan	>3D	>6D

*NOTE: The plane should be selected as far as practicable from a fan. Flow straighteners may be required to ensure the position chosen meets the check criteria listed in Items (a) to (f) below.*

- The gas flow is basically in the same direction at all points along each sampling traverse;*
- The gas velocity at all sampling points is greater than 3 m/s;*
- The gas flow profile at the sampling plane shall be steady, evenly distributed and not have a cyclonic component which exceeds an angle of 15° to the duct axis, when measured near the periphery of a circular sampling plane;*
- The temperature difference between adjacent points of the survey along each sampling traverse is less than 10% of the absolute temperature, and the temperature at any point differs by less than 10% from the mean;*
- The ratio of the highest to lowest pitot pressure difference shall not exceed 9:1 and the ratio of highest to lowest gas velocities shall not exceed 3:1. For isokinetic testing with the use of impingers, the gas velocity ratio across the sampling plane should not exceed 1.6:1; and*
- The gas temperature at the sampling plane should preferably be above the dewpoint.*

The sampling plane for EPL Point 1 was compliant with the AS4323.1.

## 3.0 Methodology

### 3.1 NATA Accredited Methods

The following methods are accredited with the National Association of Testing Authorities (NATA) (accreditation number 2778 (14391)) and are approved for the sampling and analysis of gases. Specific details of the methods are available on request.

All sampling and analysis is conducted according to the methods in **Table 2**.

**Table 2 AECOM NATA Endorsed Methods**

NSW EPA Approved Methods	USEPA Methods	Method Title
AS4323.1	USEPA (2000) Method 1	Selection of sampling positions
AS4323.2	USEPA (2000) Method 5	Determination of total particulate matter – isokinetic manual sampling – gravimetric method
NSW EPA TM-2	USEPA (2000) Method 2	Determination of stack gas velocity and volumetric flow rate (type s pitot tube)
NSW EPA TM-22	USEPA (2000) Method 4	Determination of moisture content in stack gases
NSW EPA TM-23	USEPA (2000) Method 3	Gas analysis for the determination of dry molecular weight
NSW EPA OM-5	USEPA (1997) Method 201A	Determination of PM <sub>10</sub> emissions
NSW EPA TM-12,13 and 14	USEPA Method 29	Determination of metal emissions from stationary sources

All parameters are reported adjusted to 0°C at 1 atmosphere and dry gas.

### 3.2 Equipment Calibration

AECOM has a calibration schedule to ensure the emission testing equipment is maintained in good order and with known calibration. Equipment used in this project was calibrated according to the procedures and frequency identified in the AECOM calibration schedule. Details of the schedule and the calibration calculations are available on request.

## 4.0 Sampling Location

### 4.1 Sampling Location Summary

**Table 3** provides a summary of the location sampled by AECOM on 14 March 2019.

**Table 3 Sampling Location Summary**

Discharge Description	Shredder Baghouse Stack (EPL Point 1)
Duct Shape	Circular
Construction Material	Metal
Duct Diameter (mm)	760
Minimum No. Sampling Points	12
Sampling Ports	2
Min. Points/Traverse	6
Disturbance	No
Distance from Upstream Disturbance	6.6D
Type of Disturbance	Bend
Distance from Downstream Disturbance	2.6D
Type of Disturbance	Stack Exit
Ideal Sampling Location	Yes
Correction Factors Applied	No
Total No. Points Sampled	12
Points/Traverse	6
Sampling Performed to Standard <sup>1</sup>	Yes

<sup>1</sup> AS 4323.1 Section 4.1

D = Diameters



## 5.0 Results

A summary of air emission test results is shown in **Table 4**. Detailed results along with gas stream properties during the testing period can be found in **Table 5**. Speciated Hazardous Substances (Metals) results are presented in **Table 6**. Emission concentrations are converted to standard conditions of 0°C, dry gas and 1 atm pressure for comparison with regulatory limits.

Field sheets and final calculations recorded during the project are attached as **Appendix A**. Laboratory reports can be referred to in **Appendix B**.

AECOM has a calculated limit of uncertainty in regards to results. The estimation of measurement uncertainty in source testing is conducted to provide an indication of the precision of the measurement result and a degree of confidence in the range of values the reported result may represent. The measurement of uncertainty has been calculated at  $\pm 13.6\%$ .

**Table 4 Shredder Baghouse Emission Results Summary, 14 March 2019**

Parameter	Emission Concentration (EPL Point 1)	Emission Concentration Limit
Total Particulate (TP) (mg/m <sup>3</sup> )	9.2	100
Fine Particulate (PM <sub>10</sub> ) (mg/m <sup>3</sup> )	2.7	N/A
Lead (mg/m <sup>3</sup> )	0.0052	5
Mercury (mg/m <sup>3</sup> )	0.00021	1
Total Hazardous Substances (Metals) (mg/m <sup>3</sup> )	0.023	N/A

Results from testing conducted on EPL Point 1 on 14 March 2019 are below the regulatory limits listed in EPL 5345.

**Table 5 Fine Particulate (PM<sub>10</sub>), Total Particulate and Hazardous Substance (Metals) Results, 14 March 2019**

Sampling Conditions:		
Stack internal diameter at test location	760 mm	306.7 K
Stack gas temperature (average)	33.5 °C	
Stack pressure (average)	1014 hPa	
Stack gas velocity (average, stack conditions)	7.3 m/s	
Stack gas flowrate (stack conditions)	3.3 m³/s	
Stack gas flowrate (0°C, dry gas, 1 atm pressure)	2.9 m³/s	
Fine Particulate (PM <sub>10</sub> ) Testing		
Test Period	12:55 -	14:25
Fine Particulate (PM <sub>10</sub> ) Mass	2.8 mg	
Gas Volume Sampled	1.03 m³	
Fine Particulate (PM <sub>10</sub> ) Emission* <sup>1</sup>	2.7 mg/m³	
Fine Particulate (PM <sub>10</sub> ) Mass Emission Rate* <sup>2</sup>	7.8 mg/s	
Regulatory Limit	N/A	
Total Particulate Testing		
Test Period	12:55 -	14:25
Total Particulate Mass	9.4 mg	
Gas Volume Sampled	1.02 m³	
Total Particulate Emission* <sup>1</sup>	9.2 mg/m³	
Total Particulate Mass Emission Rate* <sup>2</sup>	27 mg/s	
Regulatory Limit	100 mg/m³	
Hazardous Substances (Metals) Testing		
Test Period	12:55 -	14:25
Hazardous Substances (Metals) Mass	0.022 mg	
Gas Volume Sampled	0.956 m³	
Hazardous Substances (Metals) Emission* <sup>1</sup>	0.023 mg/m³	
Hazardous Substances (Metals) Mass Emission Rate* <sup>2</sup>	0.067 mg/s	
Regulatory Limit	N/A	
Moisture Content (%)	1.9	
Gas Density (dry at 1 atmosphere)	1.29 kg/m³	
Dry Molecular Weight	28.8 g/g-mole	

Notes \*1 Emission concentration at Standard conditions of 0°C, 1 atm, dry gas

\*2 Mass emission rate determined from pre and post-test sampling flow measurements and the respective test moisture content. See Q<sub>std</sub> in field sheets and final calculations "Stack Analysis - Final Calculations" for each test.

**Table 6 Hazardous Substances (Metals) Elemental Analysis Results, 14 March 2019**

Sample	Total Particulate Metals (mg)	Total Particulate Metals (mg/m <sup>3</sup> )	Total Gaseous Metals (mg)	Total Gaseous Metals (mg/m <sup>3</sup> )	Total Oxidisable Mercury (mg)	Total Oxidisable Mercury (mg/m <sup>3</sup> )	Total (mg)	Total (mg/m <sup>3</sup> )	Mass Emission Rate (mg/s)
Antimony	0.00015	0.00016	0.00015	0.00016			0.0003	0.00031	0.0009
Arsenic	<0.00046	<0.00048	<0.0001	<0.0001			<0.0001	<0.0001	<0.00029
Beryllium	<0.00005	<0.000052	<0.0001	<0.0001			<0.0001	<0.0001	<0.00029
Cadmium	0.00037	0.00039	<0.0002	<0.00021			0.0004	0.00042	0.0012
Chromium	0.0011	0.0012	0.00049	0.00051			0.002	0.0021	0.0061
Cobalt	<0.0001	<0.0001	<0.0001	<0.0001			<0.0001	<0.0001	<0.00029
Copper	0.0024	0.0025	0.003	0.0031			0.005	0.0052	0.015
Lead	0.0033	0.0035	0.0013	0.0014			0.005	0.0052	0.015
Magnesium	<0.29	<0.3	0.029	0.03			0.03	0.031	0.09
Manganese	0.0019	0.002	0.0011	0.0012			0.003	0.0031	0.009
Mercury	0.00005	0.000052	0.000048	0.00005	0.00015	0.00016	0.0002	0.00021	0.00061
Nickel	0.00084	0.00088	0.0005	0.00052			0.001	0.001	0.0029
Selenium	0.00005	0.000052	<0.0005	<0.00052			0.00005	0.000052	0.00015
Thallium	<0.0001	<0.0001	<0.0001	<0.0001			<0.0001	<0.0001	<0.00029
Tin	0.008	0.0084	0.0038	0.004			0.01	0.01	0.029
Vanadium	<0.00299	<0.0031	<0.0039	<0.0041			<0.0001	<0.0001	<0.00029
Zinc	<6.6	<6.9	0.023	0.024			0.02	0.021	0.061
<b>Total Hazardous Metals*</b>	<b>0.0078</b>	<b>0.0082</b>	<b>0.0036</b>	<b>0.0038</b>	<b>0.00015</b>	<b>0.00016</b>	<b>0.022</b>	<b>0.023</b>	<b>0.066</b>
<b>Total Metals</b>	<b>0.018</b>	<b>0.019</b>	<b>0.062</b>	<b>0.065</b>			<b>0.077</b>	<b>0.081</b>	<b>0.23</b>

\* Total does not include Copper, Magnesium and Zinc as they are classed non-hazardous

This page has been left blank intentionally.

# Appendix A

Field Sheets (19 pages)

## Appendix A    Field Sheets (19 pages)

## Emission Measurement Calculations Spreadsheet

Q4AN(EV)-332-FM31

## OneSteel Hexham

AECOM's Project Number: 60493017

Emission Source: Shredder Stack

Date Sampled: 14-Mar-19

ANALYTE(S)	METHOD
Fine Particulate (PM10)	NSW EPA OM - 5
Total Particulate	NSW EPA TM - 15
Hazardous Substances (Metals)	NSW EPA TM - 12, 13 & 14

Observations made during testing period:

Sampling Performed By:



  
for Sharn Crosdale  
for Sam Hamilton

## Emission Measurement Calculations Spreadsheet

Q4AN(EV)-332-FM31

## STACK ANALYSIS - PRE-SAMPLING

Date: 14-Mar-19  
Client: OneSteel Hexham  
AECOM's Project No: 60493017  
Stack/Duct Description: Shredder Stack  
Test 1: Fine Particulate (PM10)  
Test 2: Total Particulate  
Test 3: Hazardous Substances (Metals)

Measurement/Observations				
Stack Internal Dimensions:				
Diameter	760 mm		Cross Sectional Area :	
OR	Length	Width	0.45 m <sup>2</sup>	
Length/Width (mm)			Minimum No. of	
Equivalent Diameter	N/A	mm	sampling points= 12	
Distance from sampling plane to nearest disturbances:			Total No. of sampling points = 12	
Upstream (m) = 5			PM2.5/10= 12	
No. Diameters = 6.6			No. of sampling traverses/ports sampled = 2	
Type of Upstream Disturbance: Fan Entry			PM2.5/10= 2	
Downstream (m) = 2			No. of sampling points on each traverse/port = 6	
No. Diameters = 2.6			PM2.5/10= 6	
Type of Down Stream Disturbance: Stack Exit				
Position of each sampling point, for each traverse:			Exclusion of any sample point numbers - comments:	
A B			PM10/2.5 A PM2.5/10 B	
No.	Distance from wall	S-type Pitot distances	Distance from wall	S-Type Pitot distances
1	33	3	33	3
2	111	81	111	81
3	225	195	225	195
4	535	505	535	505
5	649	619	649	619
6	727	697	727	697
7				
8				
9				
10			Check of total points against minimum, (yes/no) - comments:	
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
Signed: 			Checked: 	



# Emission Measurement Calculations Spreadsheet

## STACK ANALYSIS - GAS COMPOSITION AND DENSITY PRE-SAMPLING

Date: 14-Mar-19  
 Client: OneSteel Hexham  
 AECOM's Project No: 60493017  
 Stack/Duct Description: Shredder Stack  
 Test 1: Fine Particulate (PM10)  
 Test 2: Total Particulate  
 Test 3: Hazardous Substances (Metals)

Sampling time start: 12:43		Sampling port No.: 1		
Measurement No.	Time sampled	CO (ppm), (dry)	O <sub>2</sub> (%), (dry)	CO <sub>2</sub> (%), (dry)
1	12:43	0	20.9	0.0
2	12:44	0	20.9	0.0
3	12:45	0	20.9	0.0
4	12:46	0	20.9	0.0
5	12:47	0	20.9	0.0
6	12:48	0	20.9	0.0
7	12:49	0	20.9	0.0
8	12:50	0	20.9	0.0
Averages:		0.0 ppm	20.9 %	0.0 %

Moisture content (M3): 0.98  
 Moisture percentage (M2): 2.40 %

### Measurements

CO: 0.0000 %,(dry)	N <sub>2</sub> : 79.1 %,(dry)
CO <sub>2</sub> : 0.0 %,(dry)	O <sub>2</sub> : 20.9 %,(dry)
Gas Compositions converted to wet basis:	
CO: 0.0000 %,(wet)	N <sub>2</sub> : 77.2 %,(wet)
CO <sub>2</sub> : 0.0 %,(wet)	O <sub>2</sub> : 20.4 %,(wet)
H <sub>2</sub> O: 2.40 % (=M2)	
Therefore, stack gas density (GD) = 1.28 kg/m <sup>3</sup> (0°C, wet, 1 atm pressure)	
Therefore, stack gas density (GD) = 1.29 kg/m <sup>3</sup> (0°C, dry, 1 atm pressure)	

ANZ

## Emission Measurement Calculations Spreadsheet

Q4AN(EV)-332-FM31

## STACK ANALYSIS - GAS COMPOSITION AND DENSITY POST-SAMPLING

Date: 14-Mar-19  
 Client: OneSteel Hexham  
 AECOM's Project No: 60493017  
 Stack/Duct Description: Shredder Stack  
 Test 1: Fine Particulate (PM10)  
 Test 2: Total Particulate  
 Test 3: Hazardous Substances (Metals)

Sampling time start: 14:12		Sampling port No.: 1		
Measurement No.	Time sampled	CO (ppm), (dry)	O <sub>2</sub> (%), (dry)	CO <sub>2</sub> (%), (dry)
1	14:12	0	20.9	0.0
2	14:13	0	20.9	0.0
3	14:14	0	20.9	0.0
4	14:15	0	20.9	0.0
5	14:16	0	20.9	0.0
6	14:17	0	20.9	0.0
7	14:18	0	20.9	0.0
8	14:19	0	20.9	0.0
Averages:		0.0 ppm	20.9 %	0.0 %

Moisture content (M3): 0.98

Moisture percentage (M2): 1.89 %

## Measurements

CO: 0.0000 %,(dry)	N <sub>2</sub> : 79.1 %,(dry)
CO <sub>2</sub> : 0.0 %,(dry)	O <sub>2</sub> : 20.9 %,(dry)
Gas Compositions converted to wet basis:	
CO: 0.0000 %,(wet)	N <sub>2</sub> : 77.6 %,(wet)
CO <sub>2</sub> : 0.0 %,(wet)	O <sub>2</sub> : 20.5 %,(wet)
H <sub>2</sub> O: 1.89 % (=M2)	
Therefore, stack gas density (GD) = 1.28 kg/m <sup>3</sup> (0°C, wet, 1 atm pressure)	
Therefore, stack gas density (GD) = 1.29 kg/m <sup>3</sup> (0°C, dry, 1 atm pressure)	

## Q4AN(EV)-332-FM31

Date: 14-Mar-19  
Client: OneSteel Hexham  
AECOM's Project No: 60493017  
Stack/Duct Description: Shredder Stack  
Test 1: Fine Particulate (PM10)  
Test 2: Total Particulate  
Test 3: Hazardous Substances (Metals)

Static Pressure (Dwyer) (Pa):	kPa
Static Pressure (U-tube, if required) :	-5.1 mm
Absolute pressure in stack (hPa) :	1013.50 hPa



## STACK ANALYSIS

### SAMPLING OF FINE PARTICULATE (PM<sub>10</sub>)

Date: 14-Mar-19

Date: 14-Mar-19  
Client: OneSteel Hexham

AECOM's Project No: 60493017

Stack Description No.: Shredder Stack

Sample Nozzle No.: fine10

Sample Nozzle Area ( $A_n$ ): 5.82  $\times 10^{-5} \text{ m}^2$

Sampling Port No.: 1 to 2

Thimble No: M29

Page No: 1 of 1

Blank thimble No: 0

### Leak Check (Pre-Sampling)

Meter start: 5500.3022 Meter finish:

Time start: 12:46 Time finish:

### Leak Check (Post Sampling)

Meter start: 5501.4672 Meter finish: 5501.4672

Meter start: 5501:4072 Meter finish: 5501:4072  
Time start: 14:29 Time finish: 14:30

Therefore, leakage rate = no leak L/min

Therefore, leakage rate = no leak L/min

( $>0.1$  l/min. is unacceptable)

( $>0.1$  l/min. is unacceptable)

Repeat:

Repeat:

Comments:

Repeat.

Comments:

### Sampling Record Table

Barometric Pressure: 1014 hPa (start):

1014 hPa (finish)

Meter start: 5500.3038

Time start: 12:55

Meter correction factor (GMf) : 0.9900

Sampling Position No.	Stopwatch Time at Sampling Position	Distance from far wall (mm)	Isokinetic Flowrate (L/min)	Meter Inlet Temp. (°C)	Meter Outlet Temp. (°C)	Impinger Train Outlet Temp (°C)	Flowrate Attained (Y/N)
1/1	0:07:00	33	12.9	30.6	27.5	y	Yes
1/2	0:07:00	111	12.9	31.0	28.0	y	Yes
1/3	0:07:15	225	12.9	32.0	28.0	y	Yes
1/4	0:08:15	535	12.9	33.0	28.0	y	Yes
1/5	0:07:45	649	12.9	33.0	28.0	y	Yes
1/6	0:07:45	727	12.9	33.0	28.0	y	Yes
2/1	0:07:45	33	12.9	33.0	29.0	y	Yes
2/2	0:07:30	111	12.9	34.0	29.0	y	Yes
2/3	0:07:30	225	12.9	35.0	29.0	y	Yes
2/4	0:08:00	535	12.9	35.0	30.0	y	Yes
2/5	0:06:15	649	12.9	35.0	30.0	y	Yes
2/6	0:08:00	727	12.9	35.0	30.0	y	Yes
Averages				33.3	28.7	no result	

Meter Finish:	5501.4650
---------------	-----------

Time Finish:	14:25
--------------	-------

Total Condensate collected: 0 ml

Silica gel No(s) used: G024

## STACK ANALYSIS

### SAMPLING OF TOTAL PARTICULATE

Date: 14-Mar-19

**Client:** OneSteel Hexham

AECOM's Project No: 60493017

Stack Description No.: Shredder Stack

Sample Nozzle No.: s10

Sample Nozzle Area (A<sub>n</sub>): 2.98 x 10<sup>-5</sup> m<sup>2</sup>

Sampling Port No.: 1 to 2

Thimble No: N23

Page No: 1 of 1

Blank thimble No:

### Leak Check (Pre-Sampling)

Meter start: 549.7956 Meter finish:

Time start: 12:48 Time finish:

### Leak Check (Post Sampling)

Meter start: 549 9264 Meter finish: 549 9264

Meter start: 549.9204 Meter finish: 549.9204  
Time start: 14:31 Time finish: 14:32

Therefore, leakage rate = no leak L/min

Therefore, leakage rate = no leak L/min

( $>0.1$  l/min. is unacceptable)

( $>0.1$  l/min. is unacceptable)

Repeat:

Repeat:

Repeat: \_\_\_\_\_  
Comments: \_\_\_\_\_

Repeat:  
Comments:

### Sampling Record Table

Barometric Pressure: 1014 hPa (start):

Meter start: 549.7978

Meter correction factor (GMf) : 1.0000

1014 hPa (finish)

Time start: 12:55

Sampling Position No.	Stopwatch Time at Sampling Position	Distance from far wall (mm)	Isokinetic Flowrate (L/min)	Meter Inlet Temp. (°C)	Meter Outlet Temp. (°C)	Impinger Train Outlet Temp (°C)	Flowrate Attained (Y/N)
1/1	0:07:30	33	11.8	29.0	27.0	y	Yes
1/2	0:15:00	111	11.8	30.0	27.0	y	Yes
1/3	0:22:30	225	12.2	30.0	28.0	y	Yes
1/4	0:30:00	535	13.5	31.0	28.0	y	Yes
1/5	0:37:30	649	13.0	31.0	28.0	y	Yes
1/6	0:45:00	727	13.0	31.0	28.0	y	Yes
2/1	0:52:30	33	12.8	31.0	28.0	y	Yes
2/2	1:00:00	111	12.7	31.0	28.0	y	Yes
2/3	1:07:30	225	12.5	32.0	29.0	y	Yes
2/4	1:15:00	535	13.5	33.0	29.0	y	Yes
2/5	1:22:30	649	10.3	32.0	29.0	y	Yes
2/6	1:30:00	727	13.0	32.0	29.0	y	Yes
Averages				31.1	28.2	no result	

Meter Finish: 550.9250

Total Condensate collected: 3 ml

Time Finish:	14:25
--------------	-------

Silica gel No(s) used: 026

## Emission Measurement Calculations Spreadsheet

Q4AN(EV)-332-FM31

## STACK ANALYSIS

### SAMPLING OF HAZARDOUS SUBSTANCES (METALS)

Date: 14-Mar-19

Date: 14-Mar-19  
Client: OneSteel Hexham

AECOM's Project No: 60493017

Stack Description No.: Shredder Stack

Sample Nozzle No.: g61

Sample Nozzle Area (A<sub>n</sub>): 2.73 x 10<sup>-5</sup> m<sup>2</sup>

Sampling Port No.: 1 to 2

Thimble No: 0

Page No: 1 of 1

Blank thimble No:

### Leak Check (Pre-Sampling)

Meter start: 656.6854 Meter finish:

Time start: 12:50 Time finish:

### Leak Check (Post Sampling)

Meter start: 657.7392 Meter finish: 657.7392

Meter start: 657.7552 Meter finish: 657.7552  
Time start: 14:33 Time finish: 14:34

Therefore, leakage rate = no leak L/min

Therefore, leakage rate = no leak L/min

( $>0.1$  l/min. is unacceptable)

( $>0.1$  l/min. is unacceptable)

Repeat:

Repeat:

Repeat:  
Comments:

Repeat:  
Comments:

### Sampling Record Table

Barometric Pressure: 1014 hPa (start):

1014 hPa (finish)

Meter start: 656.6882

Time start: 12:55

Meter correction factor (GMf) : 1.0057

Sampling Position No.	Stopwatch Time at Sampling Position	Distance from far wall (mm)	Isokinetic Flowrate (L/min)	Meter Inlet Temp. (°C)	Meter Outlet Temp. (°C)	Impinger Train Outlet Temp (°C)	Flowrate Attained (Y/N)
1/1	0:07:30	33	10.9	28.0	27.0	y	Yes
1/2	0:15:00	111	10.9	29.0	27.0	y	Yes
1/3	0:22:30	225	11.2	29.0	28.0	y	Yes
1/4	0:30:00	535	12.5	30.0	28.0	y	Yes
1/5	0:37:30	649	12.0	30.0	28.0	y	Yes
1/6	0:45:00	727	12.0	30.0	28.0	y	Yes
2/1	0:52:30	33	11.8	30.0	28.0	y	Yes
2/2	1:00:00	111	11.7	30.0	28.0	y	Yes
2/3	1:07:30	225	11.5	30.0	29.0	y	Yes
2/4	1:15:00	535	12.5	31.0	29.0	y	Yes
2/5	1:22:30	649	9.5	30.0	29.0	y	Yes
2/6	1:30:00	727	12.0	30.0	29.0	y	Yes
Averages				29.8	28.2	no result	

Averages	
Meter Finish:	657.7388

20.0	20.2	10:00 AM
Time Finish:		14:25

Total Condensate collected: 2 ml

Silica gel No(s) used: F21



## Q4AN(EV)-332-FM31

Static Pressure (Dwyer) (Pa): kPa  
 Static Pressure (U-tube, if required) : -4.8 mm  
 Absolute pressure in stack (hPa) : 1013.53 hPa

## Emission Measurement Calculations Spreadsheet

Q4AN(EV)-332-FM31

## STACK ANALYSIS - PM10 CALCULATIONS

Date: 14-Mar-19 Client: OneSteel Hexham  
 AECOM's Project No: 60493017 Stack/Duct Description: Shredder Stack

## 1. Gas Analysis

%			
%CO <sub>2</sub>	0.0		
%O <sub>2</sub>	20.9		
%N <sub>2</sub> +%CO	79.1		
Fraction Moisture Content, Bws	0.02	M <sub>3</sub> =	0.98

## 2. Molecular Weight of Stack Gas (Dry Basis)

Mol. Wt. of Stack Gas (dry)	28.84
Mol. Wt. of Stack Gas (wet)	28.58

## 3. Absolute Stack Pressure

	Pascals	in. Hg
Barometric Pressure (Pbar)	101400	29.93
Stack Static Pressure (Pg)	101353	29.92
Absolute Stack Pressure		29.92

## 4. Viscosity of Stack Gas

	°C	°F
Average Stack Temp.	34.0	93.2
Average Meter Temperature:	31.0	
Stack Gas Viscosity		186.2

## 5. Cyclone Flow Rate

	ft <sup>3</sup> /min	m <sup>3</sup> /min	L/min	L/s
Cyclone Flow Rate	0.46	0.0164	16.40	0.27

## 6. Nozzle Velocity, Rmin and Rmax

Nozzle Number	Nozzle Diameter	Nozzle Velocity		Rmin	Rmax	Vmin	Vmin	Vmax	Vmax
	(inches)	ft/sec	m/s	[-]	[-]	ft/sec	m/s	ft/sec	m/s
0	0.000	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!
1	0.133	79.69	26.23	0.756	1.230	60.27	19.77	98.03	32.16
2	0.159	55.83	18.38	0.723	1.251	40.38	13.25	69.83	22.91
3	0.166	51.67	17.01	0.713	1.257	36.83	12.08	64.94	21.31
4	0.000	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!
5	0.198	36.20	11.91	0.640	1.295	23.17	7.60	46.86	15.37
6	0.227	27.60	9.09	0.528	1.338	14.56	4.78	36.94	12.12
7	0.241	24.37	8.02	0.427	1.364	12.19	4.00	33.24	10.91
8	0.273	19.07	6.28	#NUM!	1.428	9.53	3.13	27.24	8.94
9	0.318	14.03	4.62	#NUM!	1.540	7.01	2.30	21.04	6.90
10	0.339	12.35	4.07	#NUM!	1.599	6.18	2.03	18.53	6.08
11	0.430	7.67	2.52	#NUM!	1.903	3.83	1.26	11.50	3.77
	Nozzle Diameter	Nozzle Diameter	Nozzle Area	Sample Rate					
Selected Nozzle	(inches)	(m)	(m <sup>2</sup> )	(L/min)					
10	0.339	0.009	0.000058	13.5					



**STACK ANALYSIS - PM10 CALCULATIONS CONTINUED**

Date: 14-Mar-19 Client: OneSteel Hexham  
AECOM's Project No: 60493017 Stack/Duct Description: Shredder Stack

7. Sampling Time	Total Run Time	90	Number of points	12
------------------	----------------	----	------------------	----

Velocity Head ( pitot) Pa	Vel Head in H <sub>2</sub> O	Sqr Root	Dwell time mins
37.28	0.15	0.39	7.0
39.24	0.16	0.40	7.1
40.22	0.16	0.40	7.2
51.99	0.21	0.46	8.2
47.09	0.19	0.43	7.8
46.11	0.19	0.43	7.7
44.15	0.18	0.42	7.6
45.13	0.18	0.43	7.6
44.15	0.18	0.42	7.6
49.05	0.20	0.44	8.0
30.41	0.12	0.35	6.3
48.07	0.19	0.44	7.9
	Average	0.42	90.00
	Square	0.17	

[illegible]

Aerodynamic Cut Size ( $u_{cyc}$ )  
187.9

PM <sub>10</sub> Flow rate at actual cyclone conditions (Q <sub>a</sub> )	0.0122
---	--------

Actual $D_{50}$	10.5
-----------------	------

## Emission Measurement Calculations Spreadsheet

Q4AN(EV)-332-FM31

## Stack Analysis - Hazardous Substances Elemental Analysis Results

Date: 14-Mar-19

Client: OneSteel Hexham

AECOM's Project No:

60493017 Stack/Duct Description: Shredder Stack

Metal	Particulate Metals Results	Gaseous Metals Results	Oxidisable Mercury Results		
	Front Half, Filter, Acetone Rinses and Acid Rinses (mg). Containers 1, 2 and 3	Back Half, Impingers + Acid Rinses (mg) Container 4	KO Impinger + Acid Rinses (mg) (5A)	KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub> + Rinses (mg) (5B)	Residue Rinse 8N HCl (mg) (If Required) (5C)
Antimony	0.00015	0.00015			
Arsenic	<0.00046	<0.0001			
Beryllium	<0.00005	<0.0001			
Cadmium	0.00037	<0.0002			
Chromium	0.0011	0.00049			
Cobalt	<0.0001	<0.0001			
Copper	0.0024	0.003			
Lead	0.0033	0.0013			
Magnesium	<0.29	0.029			
Manganese	0.0019	0.0011			
Mercury	0.00005	0.000048	<0.0001	0.00015	<0.0001
Nickel	0.00084	0.0005			
Selenium	0.00005	<0.0005			
Thallium	<0.0001	<0.0001			
Tin	0.008	0.0038			
Vanadium	<0.00299	<0.0039			
Zinc	<6.6	0.023			

Note: Where the blank has returned a less than value, half of this value was subtracted from the sample result as a blank correction ie for a blank value of <0.0005, 0.00025 was subtracted from the sample result.

\* Total does not include Copper, Magnesium and Zinc as they are classed non-hazardous

## Stack Analysis - Hazardous Substances Elemental Analysis Results Continued

Date: 14-Mar-19

Client: OneSteel Hexham

AECOM's Project No:

60493017 Stack/Duct Description: Shredder Stack

Sample	Total Particulate Metals (mg)	Total Particulate Metals (mg/m <sup>3</sup> )	Total Gaseous Metals (mg)	Total Gaseous Metals (mg/m <sup>3</sup> )	Total Oxidisable Mercury (mg)	Total Oxidisable Mercury (mg/m <sup>3</sup> )	Total (mg)	Total (mg/m <sup>3</sup> )	Mass Emission Rate (mg/s)
Antimony	0.00015	0.00016	0.00015	0.00016			0.0003	0.00031	0.0009
Arsenic	<0.00046	<0.00048	<0.0001	<0.0001			<0.0001	<0.0001	<0.00029
Beryllium	<0.00005	<0.000052	<0.0001	<0.0001			<0.0001	<0.0001	<0.00029
Cadmium	0.00037	0.00039	<0.0002	<0.00021			0.0004	0.00042	0.0012
Chromium	0.0011	0.0012	0.00049	0.00051			0.002	0.0021	0.0061
Cobalt	<0.0001	<0.0001	<0.0001	<0.0001			<0.0001	<0.0001	<0.00029
Copper	0.0024	0.0025	0.003	0.0031			0.005	0.0052	0.015
Lead	0.0033	0.0035	0.0013	0.0014			0.005	0.0052	0.015
Magnesium	<0.29	<0.3	0.029	0.03			0.03	0.031	0.09
Manganese	0.0019	0.002	0.0011	0.0012			0.003	0.0031	0.009
Mercury	0.00005	0.000052	0.000048	0.00005	0.00015	0.00016	0.0002	0.00021	0.00061
Nickel	0.00084	0.00088	0.0005	0.00052			0.001	0.001	0.0029
Selenium	0.00005	0.000052	<0.0005	<0.00052			0.00005	0.000052	0.00015
Thallium	<0.0001	<0.0001	<0.0001	<0.0001			<0.0001	<0.0001	<0.00029
Tin	0.008	0.0084	0.0038	0.004			0.01	0.01	0.029
Vanadium	<0.00299	<0.0031	<0.0039	<0.0041			<0.0001	<0.0001	<0.00029
Zinc	<6.6	<6.9	0.023	0.024			0.02	0.021	0.061
Total Hazardous Metals*	0.0078	0.0082	0.0036	0.0038	0.00015	0.00016	0.022	0.023	0.066
Total Metals	0.018	0.019	0.062	0.065			0.077	0.081	0.23

\* Total does not include Copper, Magnesium and Zinc as they are classed non-hazardous

## Emission Measurement Calculations Spreadsheet

## STACK ANALYSIS - FINAL CALCULATIONS

## Fine Particulate (PM10)

(Calculations performed in accordance with relevant test method as defined on cover page)

Date: 14-Mar-19

Client: OneSteel Hexham

AECOM's Project No:

60493017 Stack/Duct Description: Shredder Stack

## (A) Sample gas volume at standard conditions

Metered volume (MV <sub>3</sub> ):	1.1496 m <sup>3</sup>	Average barometric pressure (P <sub>BARO</sub> ):	1014 hPa
Average gas meter temp. (T <sub>M,2</sub> ):	31.0 °C	Average pressure at meter (P <sub>M,2</sub> ):	1014.00 hPa
	304.2 K		
Sample gas volume (MV <sub>4</sub> ); (0°C, dry gas, 1 atm pressure):	1.0332 m <sup>3</sup>		

## (B) PM10 concentration at standard conditions

Blank thimble No.:	0	Blank weight:	g
Thimble No. used:	M29	PM10 Weight:	0.0028 g
Final PM10 Weight (Mp1):	0.00280 g		
PM10 Concentration (C1):	= Mp1/MV <sub>4</sub> =	0.0027 g/m <sup>3</sup> (0°C, dry gas, 1 atm pressure)	
		2.7 mg/m <sup>3</sup> (0°C, dry gas, 1 atm pressure)	

CO <sub>2</sub> Basis	12 %		
Average CO <sub>2</sub> %:	0.0 %		

Therefore, C <sub>c</sub> :	= C <sub>a</sub> x 12/CO <sub>2</sub> % =	0.0027 g/m <sup>3</sup> (0°C, dry gas, 1 atm pressure, 12% CO <sub>2</sub> )
	;and C <sub>c1</sub> =	2.7 mg/m <sup>3</sup> (0°C, dry gas, 1 atm pressure, 12% CO <sub>2</sub> )

O<sub>2</sub> Basis 7 %Average O<sub>2</sub>%: 20.9 %

Therefore, C <sub>b</sub> :	= C <sub>a</sub> x (21 - O <sub>2ref</sub> %)/(21 - O <sub>2mea</sub> %)	0.38 g/m <sup>3</sup> (0°C, dry gas, 1 atm pressure, 7% O <sub>2</sub> )
	;and C <sub>b1</sub> =	380 mg/m <sup>3</sup> (0°C, dry gas, 1 atm pressure, 7% O <sub>2</sub> )

## (C) Moisture content

Silica Gel Number: G024

V <sub>v</sub> =	15.3 g (from laboratory report)	V <sub>w</sub> =	0 mL (=grams) (recorded on Laboratory Form 108)
Volume of Water Vapour Condensed (V <sub>wc(std)</sub> ) =	0.0000		
Volume of Water Vapour Condensed (V <sub>wsg(std)</sub> ) =	0.0204		

Therefore, B<sub>ws</sub> = 
$$\frac{(V_{wc(std)} + V_{wsg(std)})}{(V_{wc(std)} + V_{wsg(std)} + V_{m(std)})}$$

B<sub>ws</sub> = 1.94 %

ANZ

## Emission Measurement Calculations Spreadsheet

Q4AN(EV)-332-FM31

## STACK ANALYSIS - FINAL CALCULATIONS CONTINUED

## Fine Particulate (PM10)

## (D) Gas Composition and Density (Re-calculation)

- (i) Initial gas density for sampling: 1.28 kg/m<sup>3</sup> (from Laboratory Form 107)
- (ii) Re-calculated gas density based on moisture content in (c):  
 1.27 kg/m<sup>3</sup> (0°C, wet, 1 atm pressure)  
 1.29 kg/m<sup>3</sup> (0°C, dry, 1 atm pressure)
- (iii) Gas density at stack conditions = (ii) x  $\frac{(273.2)}{(273.2+T_s)} \times \frac{(P_s)}{(1013.25)}$   
 = 1.132 kg/m<sup>3</sup> (stack conditions, wet)

## (E) Gas Velocities

- (i) Average of pre-sampling velocities: 7.31 m/s
- (ii) Average of post-sampling velocities: 7.33 m/s
- (iii) Average of while-sampling velocities: N/A m/s
- (iv) Overall average of pre-sampling and post-sampling velocities (Vs):  
 7.32 m/s (stack conditions, wet)  
 N/A m/s (stack conditions, wet)
- (Note: (Vs) is from all individual data, **not** from (i) and (ii) alone.)

## (F) Volumetric Flowrates (Reference Method US-EPA Method 2, NSW-EPA TM-2)

$$Q_{\text{stack}} = V_s \times A = 3.32 \text{ m}^3/\text{s} \text{ (stack conditions)}$$

$$Q_{\text{std}} = Q_{\text{stack}} \times \frac{P_s}{(P_{\text{std}})} \times \frac{(T_{\text{std}})}{(T_s)} \times \frac{(100 - B_w)}{100}$$

$$Q_{\text{std}} = 2.9 \text{ m}^3/\text{s} \text{ (0°C, dry gas, 1 atm pressure)}$$

## (G) Mass Emission Rate

$$R_m = C_{1a} \times Q_{\text{std}} = 0.0078 \text{ g/s (0°C, dry gas, 1 atm pressure)}$$

$$= 7.8 \text{ mg/s (0°C, dry gas, 1 atm pressure)}$$



## Emission Measurement Calculations Spreadsheet

Q4AN(EV)-332-FM31

## STACK ANALYSIS - FINAL CALCULATIONS

## Total Particulate

(Calculations performed in accordance with relevant test method as defined on cover page)

Date: 14-Mar-19

Client: OneSteel Hexham

AECOM's Project No:

60493017 Stack/Duct Description: Shredder Stack

## (A) Sample gas volume at standard conditions

Metered volume ( $MV_3$ ):	1.1272 m <sup>3</sup>	Average barometric pressure ( $P_{BARO}$ ):	1014 hPa
Average gas meter temp. ( $T_{M,2}$ ):	29.6 °C	Average pressure at meter ( $P_{M,2}$ ):	1014.00 hPa
	302.8 K		
Sample gas volume ( $MV_4$ ); (0°C, dry gas, 1 atm pressure):	1.0178 m <sup>3</sup>		

## (B) Total Particulate concentration at standard conditions

Blank thimble No.:		Blank weight:	g
Thimble No. used:	N23	Total Particulate Weight	0.0094 g
Final Total Particulate Weight ( $M_{p1}$ ):	0.00940 g		
Total Particulate Concentration ( $C_1$ ):	$= M_{p1}/MV_4 =$	0.0092 g/m <sup>3</sup> (0°C, dry gas, 1atm pressure)	
		and $C_2 =$	9.2 mg/m <sup>3</sup> (0°C, dry gas, 1atm pressure)
CO <sub>2</sub> Basis	12 %		
Average CO <sub>2</sub> %:	0.0 %		

Therefore, $C_c$ :	$= C_a \times 12/CO_2\% =$	0.0092 g/m <sup>3</sup> (0°C, dry gas, 1atm pressure, 12% CO <sub>2</sub> )
	and $C_{c1} =$	9.2 mg/m <sup>3</sup> (0°C, dry gas, 1atm pressure, 12% CO <sub>2</sub> )
O <sub>2</sub> Basis	7 %	
Average O <sub>2</sub> %:	20.9 %	
Therefore, $C_b$ :	$= C_a \times (21 - O_{2ref}\%)/(21 - O_{2mea}\%)$	1.3 g/m <sup>3</sup> (0°C, dry gas, 1atm pressure, 7% O <sub>2</sub> )
	and $C_{b1} =$	1300 mg/m <sup>3</sup> (0°C, dry gas, 1atm pressure, 7% O <sub>2</sub> )

## (C) Moisture content

Silica Gel Number:	O26	
$V_v =$	8.3 g (from laboratory report)	$V_w =$
Volume of Water Vapour Condensed ( $V_{wc(std)}$ ) =	0.0040	3 mL (=grams)
Volume of Water Vapour Condensed ( $V_{wsg(std)}$ ) =	0.0111	(recorded on Laboratory Form 108)
Therefore, $B_{ws} =$	$\frac{(V_{wc(std)} + V_{wsg(std)})}{(V_{wc(std)} + V_{wsg(std)} + V_{m(std)})}$	
$B_{ws} =$	1.46 %	

ANZ

## Emission Measurement Calculations Spreadsheet

Q4AN(EV)-332-FM31

## STACK ANALYSIS - FINAL CALCULATIONS CONTINUED

## Total Particulate

## (D) Gas Composition and Density (Re-calculation)

(i) Initial gas density for sampling:	1.28 kg/m <sup>3</sup> (from Laboratory Form 107)
(ii) Re-calculated gas density based on moisture content in (c):	1.27 kg/m <sup>3</sup> (0°C, wet, 1 atm pressure) 1.29 kg/m <sup>3</sup> (0°C, dry, 1 atm pressure)
(iii) Gas density at stack conditions =	(ii) x $\frac{(273.2)}{(273.2+T_s)} \times \frac{(P_s)}{(1013.25)}$
=	1.132 kg/m <sup>3</sup> (stack conditions, wet)

## (E) Gas Velocities

(i) Average of pre-sampling velocities:	7.31 m/s
(ii) Average of post-sampling velocities:	7.33 m/s
(iii) Average of while-sampling velocities:	N/A m/s
(iv) Overall average of pre-sampling and post-sampling velocities (Vs):	7.32 m/s (stack conditions, wet) N/A m/s (stack conditions, wet)
<b>(Note:</b> (Vs) is from all individual data, <b>not</b> from (i) and (ii) alone.)	

## (F) Volumetric Flowrates (Reference Method US-EPA Method 2, NSW-EPA TM-2)

Qstack =	Vs x A =	3.32 m <sup>3</sup> /s (stack conditions)
Qstd =	Qstack x $\frac{P_s}{(P_{std})} \times \frac{(T_{std})}{(T_s)} \times \frac{(100 - B_w)}{100}$	
Qstd =	2.9 m <sup>3</sup> /s (0°C, dry gas, 1 atm pressure)	

## (G) Mass Emission Rate

Rm =	C <sub>1a</sub> x Qstd =	0.027 g/s (0°C, dry gas, 1 atm pressure )
	=	27 mg/s (0°C, dry gas, 1 atm pressure )

## Emission Measurement Calculations Spreadsheet

Q4AN(EV)-332-FM31

## STACK ANALYSIS - FINAL CALCULATIONS

## Hazardous Substances (Metals)

(Calculations performed in accordance with relevant test method as defined on cover page)

Date: 14-Mar-19

Client: OneSteel Hexham

AECOM's Project No:

60493017 Stack/Duct Description: Shredder Stack

## (A) Sample gas volume at standard conditions

Metered volume (MV <sub>3</sub> ):	1.0566 m <sup>3</sup>	Average barometric pressure (P <sub>BARO</sub> ):	1014 hPa
Average gas meter temp. (T <sub>M,2</sub> ):	29.0 °C	Average pressure at meter (P <sub>M,2</sub> ):	1014.00 hPa
	302.2 K		
Sample gas volume (MV <sub>4</sub> ); (0°C, dry gas, 1 atm pressure):	0.9559 m <sup>3</sup>		

## (B) Metals concentration at standard conditions

Blank thimble No.:		Blank weight:	g
Thimble No. used:	0	Metals Weight:	0.000022 g
Final Metals Weight (Mp1):	0.00002 g		
Metals Concentration (C1):	=M <sub>p1</sub> /MV <sub>4</sub> =	0.000023 g/m <sup>3</sup> (0°C, dry gas, 1atm pressure)	
		and C <sub>2</sub> =	0.023 mg/m <sup>3</sup> (0°C, dry gas, 1atm pressure)
CO <sub>2</sub> Basis	12 %		
Average CO <sub>2</sub> %:	0.0 %		

Therefore, C <sub>c</sub> :	= C <sub>a</sub> x 12/CO <sub>2</sub> % =	0.000023 g/m <sup>3</sup> (0°C, dry gas, 1atm pressure, 12% CO <sub>2</sub> )
	and C <sub>c1</sub> =	0.023 mg/m <sup>3</sup> (0°C, dry gas, 1atm pressure, 12% CO <sub>2</sub> )

O<sub>2</sub> Basis 7 %Average O<sub>2</sub>%: 20.9 %

Therefore, C <sub>b</sub> :	=C <sub>a</sub> x (21 - O <sub>2ref</sub> %)/(21 - O <sub>2mea</sub> %)	0.0032 g/m <sup>3</sup> (0°C, dry gas, 1atm pressure, 7% O <sub>2</sub> )
	and C <sub>b1</sub> =	3.2 mg/m <sup>3</sup> (0°C, dry gas, 1atm pressure, 7% O <sub>2</sub> )

## (C) Moisture content

Silica Gel Number: F21

V <sub>v</sub> =	14.7 g (from laboratory report)	V <sub>w</sub> =	2 mL (=grams) (recorded on Laboratory Form 108)
Volume of Water Vapour Condensed (V <sub>wc(std)</sub> ) =	0.0027		
Volume of Water Vapour Condensed (V <sub>wsg(std)</sub> ) =	0.0196		

Therefore, B<sub>ws</sub> = 
$$\frac{(V_{wc(std)} + V_{wsg(std)})}{(V_{wc(std)} + V_{wsg(std)} + V_{m(std)})}$$

B<sub>ws</sub> = 2.28 %

ANZ

## Emission Measurement Calculations Spreadsheet

Q4AN(EV)-332-FM31

## STACK ANALYSIS - FINAL CALCULATIONS CONTINUED

## Hazardous Substances (Metals)

## (D) Gas Composition and Density (Re-calculation)

(i) Initial gas density for sampling:	1.28 kg/m <sup>3</sup> (from Laboratory Form 107)
(ii) Re-calculated gas density based on moisture content in (c):	1.28 kg/m <sup>3</sup> (0°C, wet, 1 atm pressure) 1.29 kg/m <sup>3</sup> (0°C, dry, 1 atm pressure)
(iii) Gas density at stack conditions =	(ii) x $\frac{(273.2)}{(273.2+T_s)}$ x $\frac{(P_s)}{(1013.25)}$
=	1.140 kg/m <sup>3</sup> (stack conditions, wet)

## (E) Gas Velocities

(i) Average of pre-sampling velocities:	7.31 m/s
(ii) Average of post-sampling velocities:	7.33 m/s
(iii) Average of while-sampling velocities:	N/A m/s
(iv) Overall average of pre-sampling and post-sampling velocities (Vs):	7.32 m/s (stack conditions, wet) N/A m/s (stack conditions, wet)
<b>(Note: (Vs) is from all individual data, not from (i) and (ii) alone.)</b>	

## (F) Volumetric Flowrates (Reference Method US-EPA Method 2, NSW-EPA TM-2)

Qstack =	Vs x A =	3.32 m <sup>3</sup> /s (stack conditions)
Qstd =	Qstack x $\frac{P_s}{(P_{std})}$ x $\frac{(T_{std})}{(T_s)}$ x $\frac{(100 - B_w)}{100}$	
Qstd =	2.9 m <sup>3</sup> /s (0°C, dry gas, 1 atm pressure)	

## (G) Mass Emission Rate

Rm =	C <sub>1a</sub> x Qstd =	0.000067 g/s (0°C, dry gas, 1 atm pressure )
	=	0.067 mg/s (0°C, dry gas, 1 atm pressure )



## Emission Measurement Calculations Spreadsheet

Q4AN(EV)-332-FM31

EMISSION MONITORING RESULTS, SHREDDER STACK ONESTEEL HEXHAM 14-Mar-19 FINE PARTICULATE (PM10) TOTAL PARTICULATE HAZARDOUS SUBSTANCES (METALS)		
<b>Sampling Conditions:</b>		
Stack internal diameter at test location	760 mm	
Stack gas temperature (average)	33.5 °C	306.7 K
Stack pressure (average)	1014 hPa	
Stack gas velocity (average, stack conditions)	7.3 m/s	
Stack gas flowrate (stack conditions)	3.3 m <sup>3</sup> /s	
Stack gas flowrate (0°C, dry gas, 1 atm pressure)	2.9 m <sup>3</sup> /s	
<b>Fine Particulate (PM10) Testing</b>		
Test Period	12:55	- 14:25
Fine Particulate (PM10) Mass	2.8 mg	
Gas Volume Sampled	1.03 m <sup>3</sup>	
Fine Particulate (PM10) Emission*1	2.7 mg/m <sup>3</sup>	
Fine Particulate (PM10) Mass Emission Rate*2	7.8 mg/s	
Regulatory Limit	N/A	
<b>Total Particulate Testing</b>		
Test Period	12:55	- 14:25
Total Particulate Mass	9.4 mg	
Gas Volume Sampled	1.02 m <sup>3</sup>	
Total Particulate Emission*1	9.2 mg/m <sup>3</sup>	
Total Particulate Mass Emission Rate*2	27 mg/s	
Regulatory Limit	100 mg/m <sup>3</sup>	
<b>Hazardous Substances (Metals) Testing</b>		
Test Period	12:55	- 14:25
Hazardous Substances (Metals) Mass	0.022 mg	
Gas Volume Sampled	0.956 m <sup>3</sup>	
Hazardous Substances (Metals) Emission*1	0.023 mg/m <sup>3</sup>	
Hazardous Substances (Metals) Mass Emission Rate*2	0.067 mg/s	
Regulatory Limit	N/A	
<b>Moisture Content (%)</b>	1.9	
<b>Gas Density (dry at 1 atmosphere)</b>	1.29 kg/m <sup>3</sup>	
<b>Dry Molecular Weight</b>	28.8 g/g-mole	

Notes \*1 Emission concentration at Standard conditions of 0°C, 1 atm, dry gas

\*2 Mass emission rate determined from pre and post test sampling flow measurements and the respective test moisture content. See Q<sub>std</sub> in field sheets and final calculations "Stack Analysis - Final Calculations" for each test.



# Appendix B

Laboratory Results  
(8 pages)

## Appendix B    Laboratory Results (8 pages)

## CLIENT DETAILS

Contact **Colin Clarke**  
 Client **AECOM Australia Pty Ltd**  
 Address **17 Warabrook Boulevard  
 Warabrook  
 NSW 2304**

Telephone **02 8295 3600**  
 Facsimile **02 8934 0001**  
 Email **colin.clarke@aecom.com**

Project **60493017 / 3.1**  
 Order Number **60493017 / 3.1**  
 Samples **12**

## LABORATORY DETAILS

Manager **Adam Atkinson**  
 Laboratory **SGS Melbourne EH&S**  
 Address **10/585 Blackburn Road  
 Notting Hill Victoria 3168**

Telephone **+61395743200**  
 Facsimile **+61395743399**  
 Email **Au.SampleReceipt.Melbourne@sgs.com**

SGS Reference **ME309936 R0**  
 Date Received **19 Mar 2019**  
 Date Reported **04 Apr 2019**

## COMMENTS

Accredited for compliance with ISO/IEC 17025 - Testing. NATA accredited laboratory 2562(14420).

## SIGNATORIES



Adam Atkinson  
Business Manager



Ryan Zhang  
Team Leader

Sample Number	ME309936.001	ME309936.002	ME309936.003	ME309936.004
Sample Matrix	Filter	Filter	Impinger	Impinger
Sample Date	14 Mar 2019	14 Mar 2019	14 Mar 2019	14 Mar 2019
Sample Name	Metals No 1	Metals No 12	Metals No 3	Metals No 4
Parameter	Units	LOR		

Metals in Filters M29 ETC MA-1400.FL.M29.02 USEPA M29 Method: EPA29\_FILT Tested: 1/4/2019

Sb	µg total	0.05	<0.05	<0.05	-	-
As	µg total	0.05	0.41	0.46	-	-
Be	µg total	0.05	<0.05	0.05	-	-
Cd	µg total	0.05	0.22	<0.05	-	-
Cr	µg total	0.05	2.0	1.7	-	-
Co	µg total	0.05	<0.05	<0.05	-	-
Cu	µg total	0.05	0.72	1.3	-	-
Pb	µg total	0.05	2.6	0.71	-	-
Mg	µg total	0.05	250	290	-	-
Mn	µg total	0.05	2.1	1.4	-	-
Hg	µg total	0.05	<0.05	<0.05	-	-
Ni	µg total	0.05	0.47	0.23	-	-
Se	µg total	0.05	0.15	0.10	-	-
Tl	µg total	0.05	<0.05	<0.05	-	-
Sn	µg total	0.05	0.17	0.15	-	-
V	µg total	0.25	0.62	0.69	-	-
Zn	µg total	0.05	5600	6600	-	-

Metals in Impingers M29 ETC MA-1400.IMP.M29.06 (ug total) Method: EPA29\_METIMP Tested: 2/4/2019

Sb	µg total	0.1	-	-	0.2	0.2
As	µg total	0.1	-	-	<0.1	<0.1
Be	µg total	0.1	-	-	<0.1	<0.1
Cd	µg total	0.1	-	-	0.2	0.2
Cr	µg total	0.1	-	-	0.6	0.8
Co	µg total	0.1	-	-	0.2	<0.1
Cu	µg total	0.1	-	-	3.9	3.2
Pb	µg total	0.1	-	-	53	1.4
Mg	µg total	0.1	-	-	27	29
Mn	µg total	0.1	-	-	5.6	1.6
Hg	µg total	0.1	-	-	<0.1	0.1
Ni	µg total	0.1	-	-	1.2	0.6
Se	µg total	0.1	-	-	<0.1	0.3
Tl	µg total	0.1	-	-	<0.1	<0.1
Sn	µg total	0.1	-	-	0.4	8.1
V	µg total	0.1	-	-	0.7	2.3
Zn	µg total	0.1	-	-	190	23
Sample Volume*	mL	-	-	-	85	310



Sample Number	ME309936.005	ME309936.006	ME309936.007	ME309936.008
Sample Matrix	Impinger	Impinger	Impinger	Impinger
Sample Date	14 Mar 2019	14 Mar 2019	14 Mar 2019	14 Mar 2019
Sample Name	Metals No 8A	Metals No 9	Metals No 5A	Metals No 5C
Parameter	Units	LOR		

Metals in Filters M29 ETC MA-1400.FL.M29.02 USEPA M29 Method: EPA29\_FILT Tested: 2/4/2019

Sb	µg total	0.05	-	-	-	-
As	µg total	0.05	-	-	-	-
Be	µg total	0.05	-	-	-	-
Cd	µg total	0.05	-	-	-	-
Cr	µg total	0.05	-	-	-	-
Co	µg total	0.05	-	-	-	-
Cu	µg total	0.05	-	-	-	-
Pb	µg total	0.05	-	-	-	-
Mg	µg total	0.05	-	-	-	-
Mn	µg total	0.05	-	-	-	-
Hg	µg total	0.05	-	-	-	-
Ni	µg total	0.05	-	-	-	-
Se	µg total	0.05	-	-	-	-
Tl	µg total	0.05	-	-	-	-
Sn	µg total	0.05	-	-	-	-
V	µg total	0.25	-	-	-	-
Zn	µg total	0.05	-	-	-	-

Metals in Impingers M29 ETC MA-1400.IMP.M29.06 (ug total) Method: EPA29\_METIMP Tested: 1/4/2019

Sb	µg total	0.1	<0.1	<0.1	-	-
As	µg total	0.1	<0.1	<0.1	-	-
Be	µg total	0.1	<0.1	<0.1	-	-
Cd	µg total	0.1	<0.1	0.2	-	-
Cr	µg total	0.1	<0.1	0.3	-	-
Co	µg total	0.1	<0.1	<0.1	-	-
Cu	µg total	0.1	0.2	<0.1	-	-
Pb	µg total	0.1	<0.1	<0.1	-	-
Mg	µg total	0.1	<0.1	<0.1	-	-
Mn	µg total	0.1	0.4	0.1	-	-
Hg	µg total	0.1	<0.1	<0.1	<0.1	<0.1
Ni	µg total	0.1	<0.1	0.1	-	-
Se	µg total	0.1	0.3	0.2	-	-
Tl	µg total	0.1	<0.1	<0.1	-	-
Sn	µg total	0.1	0.1	4.1	-	-
V	µg total	0.1	2.3	1.6	-	-
Zn	µg total	0.1	<0.1	<0.1	-	-
Sample Volume*	mL	-	300	200	100	250

Sample Number	ME309936.009	ME309936.010	ME309936.011	ME309936.012
Sample Matrix	Impinger	Impinger	KMn04	KMn04
Sample Date	14 Mar 2019	14 Mar 2019	14 Mar 2019	14 Mar 2019
Sample Name	Metals No 8B	Metals No 11	Metals No 5B	Metals No 10
Parameter	Units	LOR		

Metals in Filters M29 ETC MA-1400.FL.M29.02 USEPA M29 Method: EPA29\_FILT Tested: 2/4/2019

Sb	µg total	0.05	-	-	-	-
As	µg total	0.05	-	-	-	-
Be	µg total	0.05	-	-	-	-
Cd	µg total	0.05	-	-	-	-
Cr	µg total	0.05	-	-	-	-
Co	µg total	0.05	-	-	-	-
Cu	µg total	0.05	-	-	-	-
Pb	µg total	0.05	-	-	-	-
Mg	µg total	0.05	-	-	-	-
Mn	µg total	0.05	-	-	-	-
Hg	µg total	0.05	-	-	-	-
Ni	µg total	0.05	-	-	-	-
Se	µg total	0.05	-	-	-	-
Tl	µg total	0.05	-	-	-	-
Sn	µg total	0.05	-	-	-	-
V	µg total	0.25	-	-	-	-
Zn	µg total	0.05	-	-	-	-

Metals in Impingers M29 ETC MA-1400.IMP.M29.06 (ug total) Method: EPA29\_METIMP Tested: 1/4/2019

Sb	µg total	0.1	-	-	-	-
As	µg total	0.1	-	-	-	-
Be	µg total	0.1	-	-	-	-
Cd	µg total	0.1	-	-	-	-
Cr	µg total	0.1	-	-	-	-
Co	µg total	0.1	-	-	-	-
Cu	µg total	0.1	-	-	-	-
Pb	µg total	0.1	-	-	-	-
Mg	µg total	0.1	-	-	-	-
Mn	µg total	0.1	-	-	-	-
Hg	µg total	0.1	<0.1	<0.1	0.2	<0.1
Ni	µg total	0.1	-	-	-	-
Se	µg total	0.1	-	-	-	-
Tl	µg total	0.1	-	-	-	-
Sn	µg total	0.1	-	-	-	-
V	µg total	0.1	-	-	-	-
Zn	µg total	0.1	-	-	-	-
Sample Volume*	mL	-	200	250	390	99



MB blank results are compared to the Limit of Reporting

LCS and MS spike recoveries are measured as the percentage of analyte recovered from the sample compared the the amount of analyte spiked into the sample.

DUP and MSD relative percent differences are measured against their original counterpart samples according to the formula : *the absolute difference of the two results divided by the average of the two results as a percentage*. Where the DUP RPD is 'NA' , the results are less than the LOR and thus the RPD is not applicable.

Metals in Filters M29 ETC MA-1400.FL.M29.02 USEPA M29 Method: EPA29\_FILT

Parameter	QC Reference	Units	LOR	MB	LCS %Recovery
Sb	LB025742	µg total	0.05	<0.05	114%
As	LB025742	µg total	0.05	<0.05	106%
Be	LB025742	µg total	0.05	<0.05	93%
Cd	LB025742	µg total	0.05	<0.05	108%
Cr	LB025742	µg total	0.05	<0.05	105%
Co	LB025742	µg total	0.05	<0.05	110%
Cu	LB025742	µg total	0.05	<0.05	104%
Pb	LB025742	µg total	0.05	<0.05	112%
Mg	LB025742	µg total	0.05	<0.05	118%
Mn	LB025742	µg total	0.05	<0.05	108%
Hg	LB025742	µg total	0.05	<0.05	104%
Ni	LB025742	µg total	0.05	<0.05	104%
Se	LB025742	µg total	0.05	<0.05	99%
Tl	LB025742	µg total	0.05	<0.05	111%
Sn	LB025742	µg total	0.05	<0.05	106%
V	LB025742	µg total	0.25	<0.25	106%
Zn	LB025742	µg total	0.05	<0.05	107%

Metals in Impingers M29 ETC MA-1400.IMP.M29.06 (µg total) Method: EPA29\_METIMP

Parameter	QC Reference	Units	LOR	MB	LCS %Recovery
Sb	LB025743	µg total	0.1	<0.1	111%
As	LB025743	µg total	0.1	<0.1	103%
Be	LB025743	µg total	0.1	<0.1	94%
Cd	LB025743	µg total	0.1	<0.1	105%
Cr	LB025743	µg total	0.1	<0.1	103%
Co	LB025743	µg total	0.1	<0.1	109%
Cu	LB025743	µg total	0.1	<0.1	104%
Pb	LB025743	µg total	0.1	<0.1	108%
Mg	LB025743	µg total	0.1	<0.1	117%
Mn	LB025743	µg total	0.1	<0.1	106%
Hg	LB025743	µg total	0.1	<0.1	
Ni	LB025743	µg total	0.1	<0.1	103%
Se	LB025743	µg total	0.1	<0.1	95%
Tl	LB025743	µg total	0.1	<0.1	107%
Sn	LB025743	µg total	0.1	<0.1	104%
V	LB025743	µg total	0.1	<0.1	105%
Zn	LB025743	µg total	0.1	<0.1	105%
Sample Volume*	LB025743	mL	-	100	NA

## METHOD

## METHODOLOGY SUMMARY

EPA 29

Analysis of acid-leachable metals by Inductively Coupled Plasma-Mass Spectrometer (ICP-MS). This method is based on USEPA 3051A, USEPA M29, and USEPA 6020A. Filters are digested using the appropriate sample preparation methods. A representative sample is extracted in concentrated acid using microwave heating by the CEM -MarsXPress (with Built-in USEPA method) Microwave Digestion system. The sample and acid are placed in a microwave vessel (TFM), which is then capped and heated in the microwave unit. After cooling, the vessel contents are diluted with DI water, then filtered/settled/centrifuged and analysed by ICP MS.

EPA29

This method covers the analysis of acid-leachable metals by Inductively Coupled Plasma-Mass Spectrometer (ICP-MS). This method is based on USEPA M29, USEPA 3015A and USEPA 6020A. Prior to analysis, samples are be solubilised or digested using the appropriate sample preparation methods.

## FOOTNOTES

IS	Insufficient sample for analysis.	LOR	Limit of Reporting
LNR	Sample listed, but not received.	↑↓	Raised or Lowered Limit of Reporting
*	NATA accreditation does not cover the performance of this service.	QFH	QC result is above the upper tolerance
**	Indicative data, theoretical holding time exceeded.	QFL	QC result is below the lower tolerance
		-	The sample was not analysed for this analyte
		NVL	Not Validated

Unless it is reported that sampling has been performed by SGS, the samples have been analysed as received. Solid samples expressed on a dry weight basis.

Where "Total" analyte groups are reported (for example, Total PAHs, Total OC Pesticides) the total will be calculated as the sum of the individual analytes, with those analytes that are reported as <LOR being assumed to be zero. The summed (Total) limit of reporting is calculated by summing the individual analyte LORs and dividing by two. For example, where 16 individual analytes are being summed and each has an LOR of 0.1 mg/kg, the "Totals" LOR will be 1.6 / 2 (0.8 mg/kg). Where only 2 analytes are being summed, the "Total" LOR will be the sum of those two LORs.

Some totals may not appear to add up because the total is rounded after adding up the raw values.

If reported, measurement uncertainty follow the ± sign after the analytical result and is expressed as the expanded uncertainty calculated using a coverage factor of 2, providing a level of confidence of approximately 95%, unless stated otherwise in the comments section of this report.

Results reported for samples tested under test methods with codes starting with ARS-SOP, radionuclide or gross radioactivity concentrations are expressed in becquerel (Bq) per unit of mass or volume or per wipe as stated on the report. Becquerel is the SI unit for activity and equals one nuclear transformation per second.

Note that in terms of units of radioactivity:

- 1 Bq is equivalent to 27 pCi
- 37 MBq is equivalent to 1 mCi

For results reported for samples tested under test methods with codes starting with ARS-SOP, less than (<) values indicate the detection limit for each radionuclide or parameter for the measurement system used. The respective detection limits have been calculated in accordance with ISO 11929.

The QC criteria are subject to internal review according to the SGS QAQC plan and may be provided on request or alternatively can be found here : <http://www.sgs.com.au/~media/Local/Australia/Documents/Technical%20Documents/MP-AU-ENV-QU-022%20QA%20QC%20Plan.pdf>

This document is issued by the Company under its General Conditions of Service accessible at [www.sgs.com/en/Terms-and-Conditions.aspx](http://www.sgs.com/en/Terms-and-Conditions.aspx). Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client only. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law .

This report must not be reproduced, except in full.

## STACK EMISSION - PARTICULATES REPORT

**Origin:** AECOM - Newcastle  
**Project:** 60493017

**Report :** 18314-0-P Page 1 of 1

**Description :** Stack Emission Samples  
Received: 15-Mar-19

**Date :** 21-Mar-19

**Report To :** Cye Buckland  
17 Warabrook Blvd, Warabrook NSW 2304

**Copy to:** FILE

---

Thimble ID		Volume (mL)	Total Particulate Matter (g)
M29	Thimble	-	0.0028
N23	Thimble	-	0.0094



## STACK EMISSION - MOISTURE REPORT

**Origin:** AECOM - Newcastle  
**Project:** 60493017

**Report :** 18314-0-M Page 1 of 1

**Description :** Stack Emission Samples  
Received: 15-Mar-19

**Date :** 21-Mar-19

**Report To :** Cye Buckland  
17 Warabrook Blvd, Warabrook NSW 2304

**Copy to:** FILE

---

Jar ID	Moisture (g)
F21	14.7
G024	15.3
O26	8.3

