

Licence 11149
 Link to Licence <http://app.epa.nsw.gov.au/prpoeoapp/>
 Name **InfraBuild -Wire**
 Address Industrial Drive, Mayfield, NSW, 2304
 Location of Monitoring Point/Area **Point 1**

Monthly Summary for: **Jan-20**
 Sample Received Monthly sample received 15/01/2020 Other daily and continuous measurements performed through January 2020
 Data Obtained 04/02/2020

| Pollutant | Units of Measure | Monitoring frequency required by | No of times measured | | | | Exceedance (Y/N) | Comments |
|------------------------|------------------|----------------------------------|----------------------|-----------|-----------|----------------------|------------------|----------|
| | | Licence | during month | Min value | Max value | 100 percentile limit | | |
| Nitrogen (ammonia) | mg/L | Monthly | 1 | N/A | 1 | 30 | N | |
| Total Copper | micrograms/L | Monthly | 1 | N/A | 7 | N/A | N | |
| Total Iron | mg/L | Monthly | 1 | N/A | 0.2 | 2 | N | |
| Total Lead | micrograms/L | Monthly | 1 | N/A | 4 | 50 | N | |
| Total Manganese | mg/L | Monthly | 1 | N/A | <0.1 | 0.5 | N | |
| Total Suspended Solids | mg/L | Monthly | 1 | N/A | 2 | 20 | N | |
| Total Zinc | mg/L | Monthly | 1 | N/A | <0.1 | 2 | N | |
| pH | pH | Continuous | Continuous | 7.5 | 8.3 | 6.5-8.5 | N | |
| Temperature | degrees Celsius | Continuous | Continuous | N/A | 42 | 42 | N | |
| Volume | kL/day | Daily | Daily | 0 | 361 | 700 | N | |

Nil Discharge on 6 days this month due to maintenance

Licence 11149
 Link to Licence <http://app.epa.nsw.gov.au/prpoeoapp/>
 Name **InfraBuild - Wire**
 Address Industrial Drive, Mayfield, NSW, 2304
 Location of Monitoring Point/Area **Point 39**

Monthly Summary for: **Feb-20**
 Sample Received Monthly sample received 16/01/2020 . Oil and Grease 20/01/2020 .
 Other daily and continuous measurements performed through January 2020.

Data Obtained 04/02/2020

| Pollutant | Units of Measure | Monitoring frequency required by Licence | No of times measured during month | Min value | Max value | 100 percentile limit | Exceedance (Y/N) | Comments |
|------------------------|------------------|--|-----------------------------------|-----------|-----------|----------------------|------------------|--|
| Chromium (hexavalent) | mg/L | Monthly | 1 | N/A | N/A | 0.01 | N | Chrome removed from Licence requirements 3/12/2019 |
| Nitrogen (ammonia) | mg/L | Monthly | 1 | N/A | <1 | N/A | N | |
| Phosphate | mg/L | Monthly | 1 | N/A | 2.4 | 10 | N | |
| Total Copper | micrograms/L | Monthly | 1 | N/A | 4 | N/A | N | |
| Total Iron | mg/L | Monthly | 1 | N/A | 0.4 | 5 | N | |
| Total Lead | micrograms/L | Monthly | 1 | N/A | <1 | N/A | N | |
| Total Manganese | mg/L | Monthly | 1 | N/A | <0.1 | 0.5 | N | |
| Total Suspended Solids | mg/L | Monthly | 1 | N/A | 3 | 50 | N | |
| Total Zinc | mg/L | Monthly | 1 | N/A | 0.2 | 3 | N | |
| Oil and Grease | mg/L | Monthly | 1 | N/A | 5 | 20 | N | |
| pH | pH | Continuous | Continuous | 7.3 | 7.7 | 6.5-8.5 | N | |
| Temperature | degrees Celsius | Continuous | Continuous | N/A | 34 | 38 | N | |
| Volume | kL/day | Daily | Daily | 0 | 195 | 200 | N | |

Note: There was one wet weather discharge under Licence Condition L3.3.