Licence	11149
Link to Licence	http://www.environment.nsw.gov.au/prpoeoapp/
Name	OneSteel Wire Pty Ltd
Address	Industrial Drive, Mayfield, NSW, 2304

Location of Monitoring Point/Area Point 1

Monthly Summary for: Sample Received Mar-16

Monthly sample received 02/03/16 Other daily and continuous measurements performed through March 2016.

Data Obtained

08-Apr-16

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured during month	Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
Nitrogen (ammonia)	mg/L	Monthly	1	N./A	2	30	N	Commonito
Total Copper	micrograms/L	Monthly	1	N./A	<10		N	
Total Iron	mg/L	Monthly	1	N./A	0.2	2	Ν	
Total Lead	micrograms/L	Monthly	1	N./A	<10	50	Ν	
Total Manganese	mg/L	Monthly	1	N./A	<0.1	0.5	Ν	
Total Suspended Solids	mg/L	Monthly	1	N./A	2	20	Ν	
Total Zinc	mg/L	Monthly	1	N./A	<0.1	2	Ν	
рН	pН	Continuous	Continuous	7.7	8.2	6.5-8.5	Ν	
Temperature	degrees Celsius	Continuous	Continuous	N/A	41.7	42	Ν	
Volume	kL/day	Daily	Daily	91	486	700	Ν	

Licence Link to Licence Name Address	OneSteel Wire Pty Industrial Drive, Ma	ment.nsw.gov.au/pr	boeoapp/					
Location of Monitoring Point/Area	Point 39							
Monthly Summary for: Sample Received	Mar-16 Monthly sample received 03/03/16 . Oil and grease 03/3/16. Other daily and continuous measurements performed through March 2016.							
Data Obtained	08-Apr-16	5						
		Monitoring frequency required by	No of times measured					
Pollutant	Units of Measure	Licence	during month	Min valu	ie Max value	100 percentile limit	Exceedance (Y/N)	Comments
Chromium (hexavalent)	mg/L	Monthly		N/A	<0.005	0.01	Ν	
Nitrogen (ammonia)	mg/L	Monthly		N/A	<1	N/A	Ν	
Phosphate	mg/L	Monthly		N/A	0.3	10	Ν	
Total Copper	micrograms/L	Monthly		N/A	<5	N/A	Ν	
Total Iron	mg/L	Monthly		N/A	0.1	5	Ν	
Total Lead	micrograms/L	Monthly		N/A	<5	N/A	Ν	
Total Manganese	mg/L	Monthly		N/A	<0.1	0.5	Ν	
Total Suspended Solids	mg/L	Monthly		N/A	2	50	Ν	
Total Zinc	mg/L	Monthly		N/A	0.2	3	Ν	
Oil and Grease	mg/L	Monthly		N/A	<5	20	Ν	
рН	pH	Continuous	Continuous	7.3	8.1	6.5-8.5	Ν	
pH Temperature		Continuous Continuous	Continuous Continuous	7.3 N/A	8.1 37.5	6.5-8.5 38	N N	

There was maintenance related discharge on the weekend of the 26 th of March of 570 m3, under Licence condition L3.1 of the Licence.