

Licence 6125
 Link to Licence <http://www.environment.nsw.gov.au/prpoeoapp/>
 Name OneSteel NSW Pty Ltd
 Address 22 Kellogg Road, Rooty Hill
 Location of Monitoring Point/Area Point 3
 Monitoring Completed Sediment Dam overflow event
 Sample Received 23-Jun-16
 Data Obtained 05-Jul-16

Pollutant	Units of Measure	Monitoring frequency required by Licence	Value	100 percentile concentration limit	Exceedance (Y/N)	Comments
Biochemical Oxygen Demand	milligrams per litre	Special frequency 1 (Each discharge)	<5	30	N/A	
Oil and Grease	milligrams per litre	Special frequency 1 (Each discharge)	<5	10	N/A	
pH	pH	Special frequency 1 (Each discharge)	9.2	6.5-8.5	N/A	In accordance with Condition L3.11 of the licence, the licensee is not taken to have exceeded the quality limits specified in L3.5 if: the overflow from Point 3 occurs solely as a result of a rainfall event at the premises that is equal to or greater than a 1 in 10 year recurrence interval over a 24 hour period; and the licensee has taken all practical measures to avoid or minimise water pollution.
Temperature	degrees Celsius	Special frequency 1 (Each discharge)		25	N/A	The temperature of the discharge was not measured at the time of discharge. However, due to the nature of the discharge, the expected temperature of the water is expected to be no greater than ambient temperature. Maximum observed temperatures over the discharge period were 18°C.
Total Suspended Solids	milligrams per litre	Special frequency 1 (Each discharge)	24	50	N/A	

*