

Licence 6125  
 Link to Licence <http://www.environment.nsw.gov.au/prpoeoapp/>  
 Name Infrabuild NSW PTY LTD  
 Address 22 Kellogg Road, Rooty Hill  
 Location of Monitoring Point/Area Point 3

Monitoring Completed Sediment Dam overflow event  
 Date Sampled: 02 - 08/03/2022  
 Sample Received 02 - 10/03/2022  
 Data Obtained 21-Mar-22

Pollutant	Units of Measure	Monitoring frequency required by Licence							100 percentile concentration	Exceedance (Y/N)
			2/03/2022	3/03/2022	4/03/2022	6/03/2022	7/03/2022	8/03/2022	limitlimit	
Biochemical Oxygen Demand	milligrams per litre	Special frequency 1 (Each discharge)	<20	<5	<5	<5	<5	<5	30	No
Oil and Grease	milligrams per litre	Special frequency 1 (Each discharge)	37	66	<10	41	<10	<10	10	Yes
pH	pH	Special frequency 1 (Each discharge)	8.8	9.6	9.4	9.6	10	9.7	6.5-8.5	Yes
Temperature	degrees Celsius	Special frequency 1 (Each discharge)	23.7	22.7	23.8	25.4	21.8	21.2	25	No
Total Suspended Solids	milligrams per litre	Special frequency 1 (Each discharge)	18	44	31	36	37	36	50	No