


Licence	11149
Link to Licence	http://app.epa.nsw.gov.au/prpoeoapp/
Name	InfraBuild -Wire
Address	Industrial Drive, Mayfield, NSW, 2304
	
Location of Monitoring Point/Area	Point 1
Monthly Summary for:	Apr-22
Sample Received	8 Composite samples received during April . Daily and continuous measurements performed through April 2022
Data Obtained	07/05/2022

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured during month	Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
Nitrogen (ammonia)	mg/L	Monthly	8	0.4	1.5	30	N	
Total Copper	micrograms/L	Monthly	8	1	4	N/A	N	
Total Iron	mg/L	Monthly	8	0.1	0.3	2	N	
Total Lead	micrograms/L	Monthly	8	1	2	50	N	
Total Manganese	mg/L	Monthly	8	0.01	0.075	0.5	N	
Total Suspended Solids	mg/L	Monthly	8	1	3	20	N	
Total Zinc	mg/L	Monthly	8	0.1	0.038	2	N	
pH	pH	Continuous	Continuous	7.7	8.3	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A	36.3	42	N	
Volume	kL/day	Daily	Daily	0	306	700	N	

Licence	11149
Link to Licence	http://app.epa.nsw.gov.au/prpoeoapp/
Address	Industrial Drive, Mayfield, NSW, 2304
Location of Monitoring Point/Area	Point 39
Monthly Summary for:	Apr-22
Sample Received	Sample received 4 th of April . Oil and Grease 5 th April . Other daily and continuous measurements performed through April 2022.
Data Obtained	06/05/2022



Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured during month	Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
Chromium (hexavalent)	mg/L	Monthly				0.01	N	Chrome removed from Licence requirements 3/12/2019
Nitrogen (ammonia)	mg/L	Monthly	1		<1	N/A	N	
Phosphorus	mg/L	Monthly	1		1.4	10	N	
Total Copper	micrograms/L	Monthly	1		3	N/A	N	
Total Iron	mg/L	Monthly	1		<0.1	5	N	
Total Lead	micrograms/L	Monthly	1		<1	N/A	N	
Total Manganese	mg/L	Monthly	1		0.007	0.5	N	
Total Suspended Solids	mg/L	Monthly	1		1	50	N	
Total Zinc	mg/L	Monthly	1		0.2	3	N	
Oil and Grease	mg/L	Monthly	1		<5	20	N	
pH	pH	Continuous	Continuous	7.3	7.7	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A	36.3	38	N	
Volume	kL/day	Daily	Daily	0	295	200	N	

Note: There was one Wet Weather discharges allowable under Section L3.3 of Licence 11149.