



<b>Licence</b>	11149
<b>Link to Licence</b>	<a href="http://app.epa.nsw.gov.au/prpoeoapp/">http://app.epa.nsw.gov.au/prpoeoapp/</a>
<b>Address</b>	Industrial Drive, Mayfield, NSW, 2304
<b>Location of Monitoring Point/Area</b>	<b>Point 39</b>
<b>Monthly Summary for:</b>	<b>Apr-22</b>
<b>Sample Received</b>	Sample received 4 th of April . Oil and Grease 5 th April . Other daily and continuous measurements performed through April 2022.
<b>Data Obtained</b>	06/05/2022



Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured during month	Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
Chromium (hexavalent)	mg/L	Monthly				0.01	N	Chrome removed from Licence requirements 3/12/2019
Nitrogen (ammonia)	mg/L	Monthly	1		<1	N/A	N	
Phosphorus	mg/L	Monthly	1		1.4	10	N	
Total Copper	micrograms/L	Monthly	1		3	N/A	N	
Total Iron	mg/L	Monthly	1		<0.1	5	N	
Total Lead	micrograms/L	Monthly	1		<1	N/A	N	
Total Manganese	mg/L	Monthly	1		0.007	0.5	N	
Total Suspended Solids	mg/L	Monthly	1		1	50	N	
Total Zinc	mg/L	Monthly	1		0.2	3	N	
Oil and Grease	mg/L	Monthly	1		<5	20	N	
pH	pH	Continuous	Continuous	7.3	7.7	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	N/A	36.3	38	N	
Volume	kL/day	Daily	Daily	0	295	200	N	

**Note:** There was one Wet Weather discharges allowable under Section L3.3 of Licence 11149.