

Licence 6125  
 Link to Licence <http://www.environment.nsw.gov.au/prpoeoapp/>  
 Name Infrabuild NSW PTY LTD  
 Address 22 Kellogg Road, Rooty Hill  
 Location of Monitoring Point/Area Point 3  
 Monitoring Completed Sediment Dam overflow event  
 Date Sampled: 04 - 10/07/2022  
 Sample Received 04 - 10/07/2022  
 Data Obtained 20-Jul-22

Pollutant	Units of Measure	Monitoring frequency required by Licence	100 percentile concentration				Exceedance (Y/N)	
			4/07/2022	5/07/2022	6/07/2022	10/07/2022		
Biochemical Oxygen Demand	milligrams per litre	Special frequency 1 (Each discharge)	<5	<5	<5	<5	30	No
Oil and Grease	milligrams per litre	Special frequency 1 (Each discharge)	<10	<10	<10	<10	10	No
pH	pH	Special frequency 1 (Each discharge)	<b>9.6</b>	<b>9.7</b>	<b>9.7</b>	<b>9.4</b>	6.5-8.5	Yes
Temperature	degrees Celsius	Special frequency 1 (Each discharge)	15.3	15.8	16.3	<25	25	No
Total Suspended Solids	milligrams per litre	Special frequency 1 (Each discharge)	38	<b>70</b>	35	21	50	Yes