

Licence	11149
Link to Licence	http://app.epa.nsw.gov.au/prpoeoapp/
Name	InfraBuild -Wire
Address	Industrial Drive, Mayfield, NSW, 2304
Location of Monitoring Point/Area Point 1	
Monthly Summary for:	Sep-22
Sample Received	Composite samples received 6 th of September . Daily and continuous measurements performed through September 2022
Data Obtained	25/10/2022



Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured during month	Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	30	N	
Total Copper	micrograms/L	Monthly	1	N/A	2	N/A	N	
Total Iron	mg/L	Monthly	1	N/A	0.1	2	N	
Total Lead	micrograms/L	Monthly	1	N/A	<1	50	N	
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A	2	20	N	
Total Zinc	mg/L	Monthly	1	N/A	<0.1	2	N	
pH	pH	Continuous	Continuous	7.7	8.25	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	16	33	42	N	
Volume	kL/day	Daily	Daily	55	338	700	N	

Licence	11149
Link to Licence	http://app.epa.nsw.gov.au/prpoeoapp/
Address	Industrial Drive, Mayfield, NSW, 2304
Location of Monitoring Point/Area	Point 39
Monthly Summary for:	Sep-22
Sample Received	Sample received 5 th of September . Oil and Grease 6 th of September. Other daily and continuous measurements performed through September 2022.
Data Obtained	25/10/2022



Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured during month	Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
Chromium (hexavalent)	mg/L	Monthly		N/A	N/A	0.01	N	Chrome removed from Licence requirements 3/12/2019
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	N/A	N	
Phosphorus	mg/L	Monthly	1	N/A	0.37	10	N	
Total Copper	micrograms/L	Monthly	1	N/A	2	N/A	N	
Total Iron	mg/L	Monthly	1	N/A	<0.1	5	N	
Total Lead	micrograms/L	Monthly	1	N/A	<1	N/A	N	
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A	1.0	50	N	
Total Zinc	mg/L	Monthly	1	N/A	0.2	3	N	
Oil and Grease	mg/L	Monthly	1	N/A	<5	20	N	
pH	pH	Continuous	Continuous	7.5	8.2	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	17.6	32	38	N	
Volume	kL/day	Daily	Daily	0	197.1	200	N	

--