

<b>Licence</b>	11149
<b>Link to Licence</b>	<a href="http://app.epa.nsw.gov.au/prpoeoapp/">http://app.epa.nsw.gov.au/prpoeoapp/</a>
<b>Name</b>	<b>InfraBuild -Wire</b>
<b>Address</b>	Industrial Drive, Mayfield, NSW, 2304
<b>Location of Monitoring Point/Area</b>	<b>Point 1</b>
<b>Monthly Summary for:</b>	<b>Mar-23</b>
<b>Sample Received</b>	Composite samples received 2 nd of March. Daily and continuous measurements performed through March 2023.
<b>Data Obtained</b>	04/04/2023



Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured during month	Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	10	N	
Total Copper	micrograms/L	Monthly	1	N/A	2	N/A	N	
Total Iron	mg/L	Monthly	1	N/A	<0.1	2	N	
Total Lead	micrograms/L	Monthly	1	N/A	<1	30	N	
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A	3	20	N	
Total Zinc	mg/L	Monthly	1	N/A	<0.1	1	N	
pH	pH	Continuous	Continuous	7.7	8.3	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	22	38	42	N	
Volume	kL/day	Daily	Daily	72	345	600	N	

Licence 11149  
 Link to Licence <http://app.epa.nsw.gov.au/prpoeoapp/>

Address Industrial Drive, Mayfield, NSW, 2304  
 Location of Monitoring Point/Area Point 39



Monthly Summary for: Mar-23  
 Sample Received Sample received 2nd of March . Oil and Grease 7th of March .  
 Other daily and continuous measurements performed through March 2023.

Data Obtained 04/04/2023

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured during month	Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	N/A	N	
Phosphorus	mg/L	Monthly	1	N/A	0.34	6	N	
Total Copper	micrograms/L	Monthly	1	N/A	4	N/A	N	
Total Iron	mg/L	Monthly	1	N/A	0.5	5	N	
Total Lead	micrograms/L	Monthly	1	N/A	<1	N/A	N	
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A	2.0	50	N	
Total Zinc	mg/L	Monthly	1	N/A	0.2	2.5	N	
Oil and Grease	mg/L	Monthly	1	N/A	<5	20	N	
pH	pH	Continuous	Continuous	7.2	7.7	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	24	36	38	N	
Volume	kL/day	Daily	Daily	0	295.1*	200	N	

\*One Wet Weather Discharge on the 28th of March, allowed under Clause L3.3 of the Licence.