Licence	11149	
Link to Licence	http://app.epa.nsw.gov.au/prpoeoapp/_	
Name	InfraBuild -Wire	🕢 InfraBuild
Address	Industrial Drive, Mayfield, NSW, 2304	
Location of Monitoring Point/Area	Point 1	
Monthly Summary for:	Nov-23	
Sample Received	Composite samples received 2 nd of November . Daily and continuous measurements perfo	ormed through November 2023.
Data Obtained	04/12/2023	

		Monitoring frequency	No of times					
Pollutant	Units of Measure	required by Licence	measured during month		Max value	100 percentile limit	Exceedance (Y/N)	Comments
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	10	N	
Total Copper	micrograms/L	Monthly	1	N/A	3	N/A	N	
Total Iron	mg/L	Monthly	1	N/A	<0.1	2	N	
Total Lead	micrograms/L	Monthly	1	N/A	<1	30	N	
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A	4	20	N	
Total Zinc	mg/L	Monthly	1	N/A	<0.1	1	N	
ЪН	pH	Continuous	Continuous	7.7	8.2	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	22	37	42	N	
Volume	kL/day	Daily	Daily	75	332	600	N	

Licence	11149	
Link to Licence	http://app.epa.nsw.gov.au/prpoeoapp/	
Address _ocation of Monitoring	Industrial Drive, Mayfield, NSW, 2304	🕢 InfraBuild
Point/Area	Point 39	
Monthly Summary for:	Nov-23	
Sample Received	Sample received 2 nd of November .Oil and Grease 7 th of November. Other daily and continuous measurements performed through November 2023.	
Data Obtained	04/12/2023	

		Monitoring frequency required by	No of times measured during					
Pollutant	Units of Measure	Licence	month	Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	N/A	N	
Phosphorus	mg/L	Monthly	1	N/A	<0.5	6	N	
Total Copper	micrograms/L	Monthly	1	N/A	5	N/A	N	
Total Iron	mg/L	Monthly	1	N/A	1.3	5	N	
Total Lead	micrograms/L	Monthly	1	N/A	<1	N/A	N	
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A	2	50	N	
Total Zinc	mg/L	Monthly	1	N/A	0.3	2.5	N	
Oil and Grease	mg/L	Monthly	1	N/A	6	20	N	
pH	рН	Continuous	Continuous	7.2	7.7	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	23	35	38	N	
Volume	kL/day	Daily	Daily	0	259*	200	N	

*One wet weather discharge under Licence section L3.3.