Licence 11149

Link to Licence <a href="http://app.epa.nsw.gov.au/prpoeoapp/">http://app.epa.nsw.gov.au/prpoeoapp/</a>

Name InfraBuild -Wire

Address Industrial Drive, Mayfield, NSW, 2304

Location of Monitoring

Point/Area Point 1

Monthly Summary for: May-24

Sample Received Composite samples received 3rd of May. Daily and continuous measurements performed through May 2024.

Data Obtained 03/06/2024

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured during month	Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	1	10	N	
Total Copper	micrograms/L	Monthly	1	N/A	2	N/A	N	
Total Iron	mg/L	Monthly	1	N/A	0.1	2	N	
Total Lead	micrograms/L	Monthly	1	N/A	<1	30	N	
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A	3	20	N	
Total Zinc	mg/L	Monthly	1	N/A	<0.1	1	N	
pH	pH	Continuous	Continuous	7.7	8.3	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	18	34	42	N	
Volume	kL/day	Daily	Daily	48	411	600	N	



Licence 11149

Link to Licence <a href="http://app.epa.nsw.gov.au/prpoeoapp/">http://app.epa.nsw.gov.au/prpoeoapp/</a>

Address Industrial Drive, Mayfield, NSW, 2304

Location of Monitoring

Point/Area Point 39

Monthly Summary for: May-24

Sample Received Samples received 5th of May. Oil and Grease 3rd of May.

Other daily and continuous measurements performed through May 2024.

Data Obtained 04/06/2024

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured during month	Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	N/A	N	
Phosphorus	mg/L	Monthly	1	N/A	<0.5	6	N	
Total Copper	micrograms/L	Monthly	1	N/A	2	N/A	N	
Total Iron	mg/L	Monthly	1	N/A	0.1	5	N	
Total Lead	micrograms/L	Monthly	1	N/A	<1	N/A	N	
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A	<1	50	N	
Γotal Zinc	mg/L	Monthly	1	N/A	0.1	2.5	N	
Oil and Grease	mg/L	Monthly	1	N/A	<5	20	N	
ЭН	рН	Continuous	Continuous	7.4	7.9	6.5-8.5	N	
Геmperature	degrees Celsius	Continuous	Continuous	14	29	38	N	
/olume	kL/day	Daily	Daily	0	532*	200	N	

<sup>\*</sup> One Wet weather discharge on 6th of May under Licence condition L3.3

