



Licence	11149	
Link to Licence	http://app.epa.nsw.gov.au/prpoeoapp/	
Name	InfraBuild -Wire	
Address	Industrial Drive, Mayfield, NSW, 2304	
Location of Monitoring Point/Area	Point 1	
Monthly Summary for:	Dec-24	
Sample Received	Composite samples received 3rd of December . Daily and continuous measurements performed through December 2024.	
Data Obtained	13/01/2025	

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured during month	Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	10	N	
Total Copper	micrograms/L	Monthly	1	N/A	2	N/A	N	
Total Iron	mg/L	Monthly	1	N/A	<0.1	2	N	
Total Lead	micrograms/L	Monthly	1	N/A	<1	30	N	
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A	2	20	N	
Total Zinc	mg/L	Monthly	1	N/A	<0.1	1	N	
pH	pH	Continuous	Continuous	7.7	8.3	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	28	41.7	42	N	
Volume	kL/day	Daily	Daily	0	290	600	N	

Licence	11149	
Link to Licence	http://app.epa.nsw.gov.au/prpoeoapp/	
Address	Industrial Drive, Mayfield, NSW , 2304	
Location of Monitoring Point/Area	Point 39	
Monthly Summary for: Sample Received	Dec-24 Samples received 3 rd & 20th of December . Oil and Grease 3 rd of December . Other daily and continuous measurements performed through December 2024.	
Data Obtained	29/01/2025	

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured during month	Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
Nitrogen (ammonia)	mg/L	Monthly	2	<1	<1	N/A	N	
Phosphorus	mg/L	Monthly	2	0.12	0.13	6	N	
Total Copper	micrograms/L	Monthly	2	5	12	N/A	N	
Total Iron	mg/L	Monthly	2	1.1	1.2	5	N	
Total Lead	micrograms/L	Monthly	2	<1	<1	N/A	N	
Total Manganese	mg/L	Monthly	2	<0.1	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	2	1	1	50	N	
Total Zinc	mg/L	Monthly	2	0.2	0.4	2.5	N	
Oil and Grease	mg/L	Monthly	2	<5	6	20	N	
pH	pH	Continuous	Continuous	7.2	8.1	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	22	33	38	N	
Volume	kL/day	Daily	Daily	0	1657*	200	N*	

* There were 2 maintenance discharges for the annual shutdown, permitted under our Licence.