

Licence	6125
Link to Licence	http://www.environment.nsw.gov.au/prpoeoapp/
Name	OneSteel NSW Pty Ltd
Address	22 Kellogg Road, Rooty Hill
Location of Monitoring Point/Area	Point 1
Monitoring Completed	Bi-annual air emissions monitoring
Sample Received	13-Oct-25
Data Obtained	13-Nov-25

Pollutant	Units of Measure	Monitoring			Exceedance (Y/N)	Comments
		frequency required by Licence	Value	100 percentile limit		
Cadmium	milligrams per cubic metre	Every 6 months	0.0013	0.2	N	
Dioxins & Furans	nanograms per cubic metre	Every 6 months	0.00200	0.1	N	
Mercury	milligrams per cubic metre	Every 6 months	0.0015	0.2	N	
Solid Particles Type 1 and Type 2	milligrams per cubic metre	Every 6 months	4.4	20	N	
substances in aggregate	milligrams per cubic metre	Every 6 months	0.051	1	N	
Volatile organic compounds	milligrams per cubic metre	Every 6 months	5.9	40	N	
Carbon dioxide	percent	Every 6 months	0.5	N/A		
Dry gas density	kilograms per cubic metre	Every 6 months	1.29	N/A		
Moisture	percent	Every 6 months	1.1	N/A		
Molecular weight of stack gases	grams per gram mole	Every 6 months	28.9	N/A		
Oxygen (O ₂)	percent	Every 6 months	20.5	N/A		
Velocity	metres per second	Every 6 months	16	N/A		
Volumetric flowrate	cubic metres per second	Every 6 months	180	N/A		