

Licence	11149
Link to Licence	http://app.epa.nsw.gov.au/prpoeoapp/
Name	InfraBuild -Wire
Address	Industrial Drive, Mayfield, NSW, 2304
Location of Monitoring Point/Area	Point 1
Monthly Summary for:	Dec-25
Sample Received	Composite samples received 2 nd of December . Daily and continuous measurements performed through December 2025.
Data Obtained	28/01/2026



Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured during month	Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	1	10	N	
Total Copper	micrograms/L	Monthly	1	N/A	5	N/A	N	
Total Iron	mg/L	Monthly	1	N/A	0.3	2	N	
Total Lead	micrograms/L	Monthly	1	N/A	<1	30	N	
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A	2	20	N	
Total Zinc	mg/L	Monthly	1	N/A	<0.1	1	N	
pH	pH	Continuous	Continuous	7.7	8.3	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	18	40	42	N	
Volume	kL/day	Daily	Daily	0	265	600	N	

Nil Discharge during a 15 Day shutdown for Maintenance.

Licence	11149
Link to Licence	http://app.epa.nsw.gov.au/prpoeoapp/
Address	Industrial Drive, Mayfield, NSW, 2304
Location of Monitoring Point/Area	Point 39
Monthly Summary for: Sample Received	Dec-25 Samples received 1 st , 19th and 20th of December . Oil and Grease 2nd of December . Other daily and continuous measurements performed through December 2025.
Data Obtained	28/01/2026



Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured during month	Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
Nitrogen (ammonia)	mg/L	Monthly	3	<1	<1	N/A	N	
Phosphorus	mg/L	Monthly	3	<0.5	<0.5	6	N	
Total Copper	micrograms/L	Monthly	3	5	38	N/A	N	
Total Iron	mg/L	Monthly	3	0.3	0.3	5	N	
Total Lead	micrograms/L	Monthly	3	<1	<1	N/A	N	
Total Manganese	mg/L	Monthly	3	<0.1	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	3	<1	2	50	N	
Total Zinc	mg/L	Monthly	3	<0.1	0.2	2.5	N	
Oil and Grease	mg/L	Monthly	1	N/A	<5	20	N	
pH	pH	Continuous	Continuous	7.1	7.7	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	24	33	38	N	
Volume	kL/day	Daily	Daily	0	1950*	200	N*	see below

* Maintenance Shutdown: Blowdown above 200 as allowed in Licence 11149.